

Arvada K-8 - Sampled 6/24/16				Resampled** 11/30/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Unit
03500-135-S	Sink near Office Workroom	13.4	ppb		
03500-130-S	Sink near Assistant Principal's Office	7.9	ppb		
03500-127-S	Sink in Clinic	7.4	ppb		
03500-142-S	Sink in Teacher's Lounge	8.0	ppb		
03500-140-S1	Sink in Library Workroom	0.9	ppb		
03500-140-S2	Sink in Library Workroom	2.0	ppb		
03500-108B-S	Sink in Conference Room 108B	27.6	ppb	1.3	ppb
03500-112-DF2	Drinking Fountain in Cafeteria near Restrooms	0.1	ppb		
03500-112-DF1	Drinking Fountain in Cafeteria near Kitchen	20.2	ppb		Fixture Removed
03500-113-S	Sink in Room 113X	16.8	ppb	7.1	ppb
03500-114-S1	Food Service-Food Prep Sink	0.9	ppb		
03500-114-S2	Food Service-Hand Sink	9.0	ppb		
03500-114-S3	Food Service-Wash Sink	2.0	ppb		
03500-114-S4	Food Service-Rinse Sink	1.6	ppb		
03500-114-S5	Food Service-Hand Sink	0.7	ppb		
03500-101H-DF	Hallway Drinking Fountain near Cafeteria	0.2	ppb		
03500-177-DF	Drinking Fountain near Circular Area Entrance	3.6	ppb		
03500-102-S1	Sink in Classroom 102	19.7	ppb	1.8	ppb
03500-102-S2	Sink in Classroom 102	11.5	ppb		
03500-102-S3	Sink in Classroom 102	18.2	ppb	5.2	ppb
03500-100H-DF	Hallway Drinking Fountain near Classroom 101	2.9	ppb		
03500-201H-DF	Hallway Drinking Fountain near Classroom 201	4.7	ppb		
03500-203-S1	Sink in Classroom 203 (202 per school signage)	544.3	ppb	3.2	ppb
03500-203-S3	Sink in Classroom 203 (202 per school signage)	766.4	ppb	0.9	ppb
03500-204-S	Sink in Prep Workroom 204 (239 per school signage)	1760.8	ppb	5.2	ppb
03500-209-S	Sink in Classroom 209	1.7	ppb		
03500-219-S2	Sink in Science Classroom 219	3.2	ppb		
03500-219-S3	Sink in Science Classroom 219	3.1	ppb		
03500-219-S1	Sink in Science Classroom 219	10.7	ppb		
03500-220-S	Sink in Science Workroom 220	11.4	ppb		
03500-221-S1	Sink in Science Classroom 221	2.6	ppb		
03500-221-S2	Sink in Science Classroom 221	3.0	ppb		
03500-221-S3	Sink in Science Classroom 221	1.9	ppb		
03500-229H-DF	Hallway Drinking Fountain near Classroom 227	0.5	ppb		
03500-230-S	Sink in Office 230	3.2	ppb		
03500-104H-DF	Hallway Drinking Fountain near Auditorium	1.5	ppb		
03500-171H-DFL	Hallway Drinking Fountain near Stage/Left	7.8	ppb		
03500-171H-DFR	Hallway Drinking Fountain near Stage/Right	5.4	ppb		
03500-112-S1	Art Room Sink	6.5	ppb		
03500-112-S2	Art Room Sink	11.8	ppb		
03500-112-S3	Art Room Sink	11.2	ppb		
03500-112-S4	Art Room Sink	3.5	ppb		
03500-160-S	Sink near Conference Room 160A	12.8	ppb		
03500-116-S1	Sink in FACS Kitchen	5.9	ppb		
03500-116-S2	Sink in FACS Kitchen	5.4	ppb		
03500-116-S3	Sink in FACS Kitchen	2.7	ppb		
03500-116-S4	Sink in FACS Kitchen	1.8	ppb		
03500-116-S5	Sink in FACS Kitchen	1.5	ppb		
03500-116-S6	Sink in FACS Kitchen	1.5	ppb		
03500-116-S7	Sink in FACS Kitchen	4.7	ppb		
03500-147-DF1	Drinking Fountain in Gym	7.8	ppb		
03500-147-DF2	Drinking Fountain in Gym	6.9	ppb		

** Resampling results after elevated fixtures were repaired, or removed and replaced.