

Blue Heron Elementary School - Sampled 7/27/16				Resampled** 11/18/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
04300-137-S	Sink in Clinic	3.1	ppb		
04300-135-S	Sink in Teacher's Planning Room	2.2	ppb		
04300-132-S	Sink in Teacher's Lounge	39.8	ppb	0.8	ppb
04300-130-S1	Food Service Sink-Wash	4.6	ppb		
04300-130-S2	Food Service Sink-Wash	6.2	ppb		
04300-130-S3	Food Service Sink-Sprayer	4.5	ppb		
04300-130-S4	Food Service Sink-Hand Sink	4.6	ppb		
04300-130-S5	Food Service Sink-Food Prep	15.0	ppb		
04300-130-S6	Food Service Sink-Hand Sink	3.9	ppb		
04300-130-S7	Food Service Sink-Sprayer	10.1	ppb		
04300-130-S8	Food Service Sink-Hand Sink	1.7	ppb		
04300-C104H-DFL	Hallway Drinking Fountain near Cafeteria/Left	2.3	ppb		
04300-C140H-DFR	Hallway Drinking Fountain near Cafeteria/Right	1.5	ppb		
04300-119-S	Sink in Classroom 119	0.6	ppb		
04300-119-SWB	Sink with Bubbler in Classroom 119	0.4	ppb		
04300-120-S	Sink in Classroom 120	0.8	ppb		
04300-120-SWB	Sink with Bubbler in Classroom 120	0.9	ppb		
04300-125-S	Sink in Classroom 125	0.5	ppb		
04300-125-SWB	Sink with Bubbler in Classroom 125	1.0	ppb		
04300-124-S	Sink in Classroom 124	0.4	ppb		
04300-124-SWB	Sink with Bubbler in Classroom 124	1.1	ppb		
04300-123-S	Sink in Classroom 123	1.0	ppb		
04300-123-SWB	Sink with Bubbler in Classroom 123	0.2	ppb		
04300-116-S	Sink in Classroom 116	11.1	ppb		
04300-116-SWB	Sink with Bubbler in Classroom 116	1.7	ppb		
04300-109-S	Sink in Classroom 109	7.8	ppb		
04300-109-SWB	Sink with Bubbler in Classroom 109	0.6	ppb		
04300-102-S	Sink in Classroom 102	0.4	ppb		
04300-102-SWB	Sink with Bubbler in Classroom 102	0.6	ppb		
04300-100-S	Sink in Classroom 100	0.9	ppb		
04300-100-SWB	Sink with Bubbler in Classroom 100	0.2	ppb		
04300-101-S	Sink in Classroom 101	1.2	ppb		
04300-101-SWB	Sink with Bubbler in Classroom 101	0.1	ppb		
04300-105-S	Sink in Classroom 105	0.4	ppb		
04300-105-SWB	Sink with Bubbler in Classroom 105	0.4	ppb		
04300-106-S	Sink in Classroom 106	0.5	ppb		
04300-106-SWB	Sink with Bubbler in Classroom 106	0.3	ppb		
04300-133-S	Sink in Music Room	18.0	ppb	0.1	ppb
04300-133-SWB	Sink with Bubbler in Music Room	0.9	ppb		
04300-C108H-DFL	Hallway Drinking Fountain near Gym/Left	0.8	ppb		
04300-156-S1	Sink in Art Room	3.5	ppb		
04300-156-S2	Sink in Art Room	3.7	ppb		
04300-162-S	Sink in Pre-K Classroom 162	0.6	ppb		
04300-162-SWB	Sink with Bubbler in Pre-K Classroom 162	0.4	ppb		
04300-163-S	Sink in Pre-K Classroom 163	0.6	ppb		
04300-163-SWB	Sink with Bubbler in Pre-K Classroom 163	0.4	ppb		
04300-168-S	Sink in Classroom 168	1.9	ppb		
04300-168-SWB	Sink with Bubbler in Classroom 168	0.3	ppb		
04300-167-S	Sink in Classroom 167	0.2	ppb		
04300-167-SWB	Sink with Bubbler in Classroom 167	1.2	ppb		
04300-166-S	Sink in Classroom 166	3.8	ppb		
04300-166-SWB	Sink with Bubbler in Classroom 166	0.1	ppb		
04300-159-S	Sink in Classroom 159	0.3	ppb		
04300-159-SWB	Sink with Bubbler in Classroom 159	0.3	ppb		
04300-171-S	Sink in Classroom 171	4.8	ppb		
04300-171-SWB	Sink with Bubbler in Classroom 171	0.3	ppb		
04300-178-S	Sink in Classroom 178	0.5	ppb		
04300-178-SWB	Sink with Bubbler in Classroom 178	0.4	ppb		
04300-179-S	Sink in Classroom 179	0.4	ppb		
04300-179-SWB	Sink with Bubbler in Classroom 179	<0.1 *	ppb		
04300-180-S	Sink in Kindergarten Classroom 180	0.2	ppb		
04300-180-SWB	Sink with Bubbler in Kindergarten Classroom 180	<0.1 *	ppb		
04300-175-S	Sink in Kindergarten Classroom 175	0.2	ppb		
04300-175-SWB	Sink with Bubbler in Kindergarten Classroom 175	0.3	ppb		
04300-174-S	Sink in Kindergarten Classroom 174	0.2	ppb		
04300-174-SWB	Sink with Bubbler in Kindergarten Classroom 174	<0.1 *	ppb		
04300-C108H-DFR	Hallway Drinking Fountain near Gym/Right	0.2***	ppb		
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results after elevated fixtures were removed and replaced.					
*** This fixture was sampled on 11/18/16.					