

Bradford Primary School - Sampled 6/15/16				Resampled** 1/19/17	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Unit
04800-109-S	Sink in Clinic Restroom	4.3	ppb		
04800-122-S1	Food Service Sink - Food Prep	4.0	ppb		
04800-122-S2	Food Service Sink - Sanitize/Rinse	5.5	ppb		
04800-122-S3	Food Service Sink - Rinse/Wash	2.9	ppb		
04800-122-S4	Food Service Sink - Hand Sink	23.3	ppb	2.6	ppb
04800-021-S	Sink in Classroom 21	1.6	ppb		
04800-020-S	Sink in Classroom 20	2.0	ppb		
04800-019-S	Sink in Classroom 19	1.3	ppb		
04800-144H-DF	Hallway Drinking Fountain	1.3	ppb		
04800-016-S	Sink in Classroom 16	1.0	ppb		
04800-015-S	Sink in Classroom 15	1.2	ppb		
04800-145H-DF	Hallway Drinking Fountain	0.8	ppb		
04800-014-S	Sink in Kindergarten Room 14	1.1	ppb		
04800-013-S	Sink in Classroom 13	4.3	ppb		
04800-160H-DF	Hallway Drinking Fountain	0.4	ppb		
04800-012-S	Sink in Classroom 12	1.6	ppb		
04800-010-S	Sink in Classroom 10	0.9	ppb		
04800-161H-DF	Hallway Drinking Fountain	2.6	ppb		
04800-009-S	Sink in Classroom 9	2.3	ppb		
04800-008-S	Sink in Classroom 8	1.3	ppb		
04800-167-S	Sink in Library Workroom	2.7	ppb		
04800-177H-DF	Hallway Drinking Fountain	0.9	ppb		
04800-007-S	Sink in Classroom 7	1.1	ppb		
04800-006-S	Sink in Classroom 6	0.9	ppb		
04800-004-S	Sink in Classroom 4	0.7	ppb		
04800-178H-DF	Hallway Drinking Fountain	0.3	ppb		
04800-003-S	Sink in Classroom 3	1.7	ppb		
04800-002-S	Sink in Kindergarten Room 2	0.9	ppb		
04800-001-S	Sink in Kindergarten Room 1	0.8	ppb		
04800-191-S	Sink in Teacher's Lounge	0.6	ppb		
04800-195H-DFL	Hallway Drinking Fountain/Left	1.0	ppb		
04800-195H-DFR	Hallway Drinking Fountain/Right	1.0	ppb		
04800-K002-S	Sink in Kindergarten Classroom K002	1.0	ppb		
04800-K001-S	Sink in Kindergarten Classroom K001	1.4	ppb		
04800-018-S	Sink in Classroom 018	***0.8	ppb		
04800-126-S1	Sink in Art Room	***1.6	ppb		
04800-126-S2	Sink in Art Room	***1.0	ppb		
04800-126-S3	Sink in Art Room	***0.9	ppb		
04800-126-S4	Sink in Art Room	***1.3	ppb		
** Resampling results after elevated fixtures were repaired, or removed and replaced.					
*** This fixture was sampled on 1/19/17.					