

Brady Exploration - Sampled 7/29/16			
CustomerSampleNumber	Description	Lead Result	Units
51700-111H-DFL	Hallway Drinking Fountain in Corridor 101/Left	10.7	ppb
51700-111H-DFR	Hallway Drinking Fountain in Corridor 101/Left	2.0	ppb
51700-109-S	Sink in Room 109	8.6	ppb
51700-119-S	Sink in Work Room 119	4.1	ppb
51700-123-S1	Food Service Sink-Hand Sink	21.4	ppb
51700-123-S3	Food Service Sink-Wash/Rinse	4.1	ppb
51700-123-S4	Food Service Sink-Rinse/Sanitize	106.1	ppb
51700-108-S	Sink outside of Cafeteria	1.4	ppb
51700-205-S1	Sink in Room 205	10.0	ppb
51700-205-S2	Sink in Room 205	4.9	ppb
51700-205-S3	Sink in Room 205	8.3	ppb
51700-205-S4	Sink in Room 205	6.9	ppb
51700-205-S6	Sink in Room 205	10.0	ppb
51700-205-S7	Sink in Room 205	13.0	ppb
51700-205-S8	Sink in Room 205	9.7	ppb
51700-202H-DFL	Hallway Drinking Fountain in Corridor 202/Left	4.0	ppb
51700-202H-DFR	Hallway Drinking Fountain in Corridor 202/Right	2.4	ppb
51700-209-S1	Sink in Room 209	12.6	ppb
51700-209-S2	Sink in Room 209	75.8	ppb
51700-209-S3	Sink in Room 209	4.4	ppb
51700-209-S4	Sink in Room 209	9.3	ppb
51700-317-S1	Sink in Room 317	2.3	ppb
51700-303H-DFL	Hallway Drinking Fountain in Corridor 303/Left	1.7	ppb
51700-303H-DFR	Hallway Drinking Fountain in Corridor 303/Right	1.6	ppb
51700-113-S	Sink in Equipment Area	13.2	ppb
51700-OH-003-S1	Sink in Room 003	1.0	ppb
51700-OH-004H-DF	Hallway Drinking Fountain outside of Room 004	0.9	ppb
51700-OH-004-S1	Sink in Room 004	1.8	ppb