

| Coronado Elementary School - Sampled 6/15/16 |   |         |       |
|--|---|---------|-------|
| CustomerSampleNumber                         | Description                                     | Results | Units |
| 09800-112-S                                  | Sink in Office Workroom                         | 1.3     | ppb   |
| 09800-113-S                                  | Sink in Clinic                                  | 1.1     | ppb   |
| 09800-128-S                                  | Sink in Teacher's Lounge                        | 0.7     | ppb   |
| 09800-120-S1                                 | Art Room Sink                                   | 4.6     | ppb   |
| 09800-120-S2                                 | Art Room Sink                                   | 5.8     | ppb   |
| 09800-120-S3                                 | Art Room Sink                                   | 5.3     | ppb   |
| 09800-120-S4                                 | Art Room Sink                                   | 5.3     | ppb   |
| 09800-214H-DF                                | Hallway Drinking Fountain                       | 0.2     | ppb   |
| 09800-211-S1                                 | Food Service Sink                               | 6.5     | ppb   |
| 09800-211-S2                                 | Food Service Sink                               | 3.2     | ppb   |
| 09800-211-S3                                 | Food Service Sink                               | 3.0     | ppb   |
| 09800-228H-S                                 | A-Pod Hallway Sink                              | 0.5     | ppb   |
| 09800-226H-DF                                | A-Pod Hallway Drinking Fountain                 | 0.2     | ppb   |
| 09800-225H-DF                                | A-Pod Hallway Drinking Fountain                 | 1.4     | ppb   |
| 09800-161H-S                                 | B-Pod Hallway Sink                              | 0.7     | ppb   |
| 09800-163H-DF                                | B-Pod Hallway Drinking Fountain                 | 1.0     | ppb   |
| 09800-137H-S                                 | C-Pod Hallway Sink                              | 0.6     | ppb   |
| 09800-141H-DF                                | C-Pod Hallway Drinking Fountain                 | 0.7     | ppb   |
| 09800-139H-DF                                | C-Pod Hallway Drinking Fountain                 | 0.5     | ppb   |
| 09800-125-S                                  | Library Workroom Sink                           | 2.1     | ppb   |
| 09800-129H-DF                                | Hallway Drinking Fountain                       | 1.2     | ppb   |
| 09800-102-SWB                                | Sink with Bubbler in Kindergarten Classroom 102 | 2.6     | ppb   |
| 09800-104-SWB                                | Sink with Bubbler in Kindergarten Classroom 104 | 3.6     | ppb   |
| 09800-R1-185-DF                              | Drinking Fountain in Temp R1-185                | 0.9     | ppb   |
| 09800-REC-085-DF                             | Drinking Fountain in Temp REC-085               | 0.6     | ppb   |
| 09800-R1-184-DF                              | Drinking Fountain in Temp R1-184                | 1.2     | ppb   |
| 09800-162H-DF                                | B-Pod Hallway Drinking Fountain                 | 0.5     | ppb   |
| 09800-R1-135-DF                              | Drinking Fountain in Temp R1-135                | 6.1     | ppb   |
| 09800-R1135-S                                | Sink in Temp R1-135                             | 2.2     | ppb   |
| 09800-R1185-S                                | Sink in Temp R1-185                             | 3.2     | ppb   |
| 09800-207-S                                  | Sink in Kitchen Restroom                        | 2.1     | ppb   |
| 09800-REC-085-S                              | Sink in Temp REC-085                            | 1.0     | ppb   |