

Dennison Elementary School - Sampled 7/26/16				Resampled** 9/7/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
52000-113-S	Sink in Clinic	22.0	ppb	5.5	ppb
52000-113-SWB	Sink With Bubbler in Clinic	2.5	ppb		
52000-114-S	Sink outside of Clinic	5.8	ppb		
52000-116-S	Sink in Work Room 116	9.6	ppb		
52000-116-SWB	Sink with Bubbler in Work Room 116	14.0	ppb		
52000-120-S	Sink in Planning Room 120	6.8	ppb		
52000-128-S	Sink in Teacher's Lounge	0.3	ppb		
52000-154-S1	Sink near Restroom across from Teacher's Lounge	1.7	ppb		
52000-154-S2	Sink near Restroom across from Teacher's Lounge	4.2	ppb		
52000-128H-DF	Hallway Drinking Fountain across from Teacher's Lounge	1.0	ppb		
52000-155-S1	Sink across from Music Room	1.7	ppb		
52000-155-S2	Sink across from Music Room	3.6	ppb		
52000-157-S2	Food Service Sink-Wash/Rinse	0.9	ppb		
52000-157-S3	Food Service Sink-Hand Sink	0.2	ppb		
52000-029-S1	Art Room Sink	5.1	ppb		
52000-029-S2	Art Room Sink	6.2	ppb		
52000-008-SWB	Sink with Bubbler in Classroom 008	3.8	ppb		
52000-008-S	Sink in Classroom 008	1.5	ppb		
52000-007-S	Sink in Classroom 007	2.4	ppb		
52000-007-SWB	Sink with Bubbler in Classroom 007	1.1	ppb		
52000-004-S	Sink in Classroom 004	0.9	ppb		
52000-004-SWB	Sink with Bubbler in Classroom 004	0.9	ppb		
52000-003-S	Sink in Classroom 003	16.9	ppb	3.2	ppb
52000-003-SWB	Sink with Bubbler in Classroom 003	6.8	ppb		
52000-028-S	Sink in Music Room	3.0	ppb		
52000-028-SWB	Sink with Bubbler in Music Room	3.1	ppb		
52000-006-S	Sink in Classroom 006	23.0	ppb	2.6	ppb
52000-006-SWB	Sink with Bubbler in Classroom 006	0.9	ppb		
52000-005-S	Sink in Classroom 005	1.4	ppb		
52000-005-SWB	Sink with Bubbler in Classroom 005	1.2	ppb		
52000-002-S	Sink in Classroom 002	31.6	ppb	1.4	ppb
52000-002-SWB	Sink with Bubbler in Classroom 002	1.3	ppb		
52000-001-S	Sink in Classroom 001	3.2	ppb		
52000-001-SWB	Sink with Bubbler in Classroom 001	1.1	ppb		
52000-009-S	Sink in Instrument/Band Room	7.6	ppb		
52000-009-SWB	Sink with Bubbler in Instrument/Band Room	3.6	ppb		
52000-156H-DF	Hallway Drinking Fountain across from Classroom 010	4.1	ppb		
52000-010-S	Sink in Classroom 010	5.7	ppb		
52000-010-SWB	Sink with Bubbler in Classroom 010	2.3	ppb		
52000-011-S	Sink in Classroom 011	9.9	ppb		
52000-011-SWB	Sink with Bubbler in Classroom 011	0.8	ppb		
52000-012-S	Sink in Classroom 012	0.9	ppb		
52000-012-SWB	Sink with Bubbler in Classroom 012	0.9	ppb		
52000-301H-DF	Hallway Drinking Fountain across from Classroom 017	0.1	ppb		
52000-018-S	Sink in Classroom 018	0.9	ppb		
52000-020-S	Sink in Classroom 020	0.7	ppb		
52000-019-S	Sink in Classroom 019	1.7	ppb		
52000-017-S	Sink in Classroom 017	1.0	ppb		
52000-016-S	Sink in Classroom 016	1.0	ppb		
52000-014-S	Sink in Classroom 014	6.5	ppb		
52000-014-SWB	Sink with Bubbler in Classroom 014	1.4	ppb		
52000-015-S	Sink in Kindergarten Classroom 015	1.2	ppb		
52000-015-SWB	Sink with Bubbler in Kindergarten Classroom 015	1.3	ppb		
52000-022-S	Sink in Kindergarten Classroom 022	0.8	ppb		
52000-022-SWB	Sink with Bubbler in Kindergarten Classroom 022	1.8	ppb		
52000-021-S	Sink in Kindergarten Classroom 021	0.6	ppb		
52000-021-SWB	Sink with Bubbler in Kindergarten Classroom 021	1.5	ppb		
52000-021-DF	Drinking Fountain in Kindergarten Classroom 021	2.4	ppb		
52000-RE-042-DF	Drinking Fountain in TEMP RE-042	0.1	ppb		
52000-REC-077-DF	Drinking Fountain in TEMP REC-077	3.1	ppb		
52000-REC-088-DF	Drinking Fountain in TEMP REC-088	0.7	ppb		
52000-R1-187-DF	Drinking Fountain in TEMP R1-187	12.7	ppb		
52000-R1-088-DF	Drinking Fountain in TEMP R1-088	8.7	ppb		
52000-R1-087-DF	Drinking Fountain in TEMP R1-087	7.7	ppb		
52000-R1-096-DF	Drinking Fountain in TEMP R1-096	6.1	ppb		

\*\* Resampling results after elevated fixtures were removed and replaced.