

Drake Middle School - Sampled 8/4/16				Resampled** 11/21/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
64500-010-S	Sink in Clinic	0.6	ppb		
64500-022H-DFL	Hallway Drinking Fountain near Offices/Left	1.7	ppb		
64500-022H-DFR	Hallway Drinking Fountain near Offices/Right	1.4	ppb		
64500-104-S1	Sink in Laboratory 104	15.3	ppb	0.3	ppb
64500-104-S2	Sink in Laboratory 104	21.9	ppb	0.4	ppb
64500-104-S3	Sink in Laboratory 104	23.4	ppb	0.3	ppb
64500-104-S4	Sink in Laboratory 104	29.6	ppb	0.1	ppb
64500-029-S	Sink in Science Prep Room 029	72.1	ppb	0.4	ppb
64500-039H-DFL	Hallway Drinking Fountain near Classroom 114/Left	1.3	ppb		
64500-039H-DFR	Hallway Drinking Fountain near Classroom 114/Right	0.7	ppb		
64500-111-S1	Sink in Laboratory 111	23.7	ppb	0.3	ppb
64500-111-S2	Sink in Laboratory 111	17.5	ppb	0.3	ppb
64500-111-S3	Sink in Laboratory 111	20.3	ppb	0.4	ppb
64500-111-S4	Sink in Laboratory 111	10.1	ppb		
64500-043-S	Sink in Science Prep Room 043	9.3	ppb		
64500-078H-DF	Hallway Drinking Fountain near Cafeteria	2.8	ppb		
64500-426XH-DF	Hallway Drinking Fountain in Gym	13.2	ppb		
64500-422XH-DF	Hallway Drinking Fountain in Locker Room	7.1	ppb		
64500-309-S	Sink in Technology Lab 309	19.1	ppb	6.4	ppb
64500-310-S	Sink in Industrial Lab 310	29.0	ppb	14.2	ppb
64500-310-DF	Drinking Fountain in Industrial Lab 310	1.9	ppb		
64500-120H-DF	Hallway Drinking Fountain by Art Room 311	20.1	ppb		Repairs pending
64500-322-S	Sink in Band Room	56.9	ppb	12.5	ppb
64500-322-SWB	Sink with Bubbler in Band Room	231.9	ppb		Repairs pending
64500-321-S1	Sink in Consumer Science Kitchen 321	1.6	ppb		
64500-321-S2	Sink in Consumer Science Kitchen 321	0.9	ppb		
64500-321-S3	Sink in Consumer Science Kitchen 321	1.1	ppb		
64500-321-S4	Sink in Consumer Science Kitchen 321	2.0	ppb		
64500-321-S5	Sink in Consumer Science Kitchen 321	1.8	ppb		
64500-321-S6	Sink in Consumer Science Kitchen 321	1.4	ppb		
64500-321-S7	Sink in Consumer Science Kitchen 321	1.7	ppb		
64500-311-S1	Sink in Art Room 311	2.7	ppb		
64500-311-S2	Sink in Art Room 311	4.8	ppb		
64500-311-S3	Sink in Art Room 311	2.6	ppb		
64500-311-S4	Sink in Art Room 311	1.9	ppb		
64500-308-S	Sink in Teacher's Lounge	2.4	ppb		
64500-146-S1	Food Service Sink-Sprayer	2.1	ppb		
64500-146-S3	Food Service Sink-Sanitize/Rinse	4.1	ppb		
64500-146-S4	Food Service Sink-Rinse/Wash	5.7	ppb		
64500-146-S5	Food Service Sink-Sprayer/Food Prep	0.9	ppb		
64500-146-S6	Food Service Sink-Food Prep	8.7	ppb		
64500-128-DF	Drinking Fountain in Cafeteria	0.2	ppb		
64500-222-S1	Sink in Laboratory 222	7.3	ppb		
64500-222-S2	Sink in Laboratory 222	17.9	ppb	0.4	ppb
64500-222-S3	Sink in Laboratory 222	22.1	ppb	0.4	ppb
64500-222-S4	Sink in Laboratory 222	12.8	ppb		
64500-246-S	Sink in Science Prep 246	13.5	ppb		
64500-204-S1	Sink in Classroom 204	15.2	ppb	0.5	ppb
64500-204-S2	Sink in Classroom 204	5.9	ppb		
64500-204-S3	Sink in Classroom 204	8.0	ppb		
64500-204-S4	Sink in Classroom 204	11.5	ppb		
64500-204A-S	Sink in Science Prep Room 204A	23.3	ppb	0.3	ppb
64500-225H-DFL	Hallway Drinking Fountain outside of Offices 205 and 206/Left	0.2	ppb		
64500-225H-DFR	Hallway Drinking Fountain outside of Offices 205 and 206/Right	0.2	ppb		
64500-210-S1	Sink in Classroom 210	21.2	ppb	0.3	ppb
64500-210-S2	Sink in Classroom 210	12.1	ppb		
64500-210-S3	Sink in Classroom 210	5.3	ppb		
64500-210-S4	Sink in Classroom 210	6.1	ppb		
64500-220-S	Sink in Science Prep Room 220	11.7	ppb		

** Resampling results after elevated fixtures were removed and replaced.