

Dunstan Middle School - Sampled 9/21/16			
CustomerSampleNumber	Description	Lead Result	Units
64700-B143H-DF	Hallway Drinking Fountain across from Classroom A105	<0.1 *	ppb
64700-A107-S1	Sink in Laboratory Room A107	7.9	ppb
64700-A107-S2	Sink in Laboratory Room A107	2.6	ppb
64700-A107-S3	Sink in Laboratory Room A107	1.6	ppb
64700-A107-S4	Sink in Laboratory Room A107	1.1	ppb
64700-A107-S5	Sink in Laboratory Room A107	1.7	ppb
64700-A107A-S	Sink in Science Prep Room A107A	4.9	ppb
64700-A143H-DF	Hallway Drinking Fountain across from Classroom B105	<0.1 *	ppb
64700-C144H-DF	Hallway Drinking Fountain across from Classroom C105	<0.1 *	ppb
64700-B122-S	Sink in Work Room B122	1.7	ppb
64700-D144H-DF	Hallway Drinking Fountain across from Classroom D105	<0.1 *	ppb
64700-E115-S1	Food Service Sink-Sprayer	4.6	ppb
64700-E115-S2	Food Service Sink-Wash	5.2	ppb
64700-E115-S3	Food Service Sink-Wash	2.8	ppb
64700-E115-S4	Food Service Sink-Food Prep	2.2	ppb
64700-E115-S5	Food Service Sink-Sprayer	6.4	ppb
64700-E115-S6	Food Service Sink-Hand Sink	1.4	ppb
64700-E115-S7	Food Service Sink-Hand Sink	1.0	ppb
64700-E115-S8	Food Service Sink-Hand Sink	0.6	ppb
64700-N102-SWB	Sink with Bubbler in Instrument/Band Room	0.4	ppb
64700-N102-S	Sink in Instrument/Band Room	0.3	ppb
64700-F101-DFL	Drinking Fountain in Gym/Left	<0.1 *	ppb
64700-F101-DFR	Drinking Fountain in Gym/Right	0.1	ppb
64700-G105-DF	Drinking Fountain in Weight Room	0.4	ppb
64700-D106XH-DFL	Hallway Drinking Fountain by Main Office Area/Left	<0.1 *	ppb
64700-D106XH-DFR	Hallway Drinking Fountain by Main Office Area/Right	<0.1 *	ppb
64700-N103-S	Sink in Clinic	0.2	ppb
64700-D136-S	Sink in Prep/Work Room D136	0.8	ppb
64700-A243H-DF	Hallway Drinking Fountain across from Classroom A205	<0.1 *	ppb
64700-B243H-DF	Hallway Drinking Fountain across from Classroom B205	<0.1 *	ppb
64700-C244H-DF	Hallway Drinking Fountain across from Classroom C205	<0.1 *	ppb
64700-D211-S	Sink in Work Room D211	0.3	ppb
64700-D244H-DF	Hallway Drinking Fountain across from Classroom D207	<0.1 *	ppb
64700-N201-S1	Sink in Consumer Science Lab N201	0.3	ppb
64700-N201-S2	Sink in Consumer Science Lab N201	0.3	ppb
64700-N201-S3	Sink in Consumer Science Lab N201	0.4	ppb
64700-N201-S4	Sink in Consumer Science Lab N201	0.4	ppb
64700-N201-S5	Sink in Consumer Science Lab N201	0.4	ppb
64700-N201-S6	Sink in Consumer Science Lab N201	0.5	ppb
64700-N201-S7	Sink in Consumer Science Lab N201	0.4	ppb
64700-N215-S1	Sink in Art Room N215	2.0	ppb
64700-N215-S2	Sink in Art Room N215	1.9	ppb
64700-N215-S3	Sink in Art Room N215	1.1	ppb
64700-N215-S4	Sink in Art Room N215	0.9	ppb
64700-N200H-DFL	Hallway Drinking Fountain outside of Consumer Science Classroom N201/Left	<0.1 *	ppb
64700-N200H-DFR	Hallway Drinking Fountain outside of Consumer Science Classroom N201/Right	0.2	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.