

Eiber Elementary School - Sampled 6/10/16				Resampled** 11-17-16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
12000-M149-S1	Food Service Sink	0.8	ppb		
12000-M149-S2	Food Service Sink	5.1	ppb		
12000-M149-S3	Food Service Sink	2.8	ppb		
12000-M149-S4	Food Service Sink	6.4	ppb		
12000-M139-DF	Drinking Fountain in Cafeteria	5.6	ppb		
12000-D0-S	Sink in Music Room D-0	5.9	ppb		
12000-D0-DF	Drinking Fountain in Music Room D-0	3.1	ppb		
12000-DS-S1	Art Room Sink	2.5	ppb		
12000-DS-S2	Art Room Sink	3.3	ppb		
12000-D4-S	Sink in Kindergarten Classroom D-4	9.1	ppb		
12000-D4-DF	Drinking Fountain in Kindergarten Classroom D-4	6.0	ppb		
12000-D3-S1	Sink in Classroom D-3	3.9	ppb		
12000-D3-S2	Sink in Classroom D-3	2.2	ppb		
12000-D2-S	Sink in Classroom D-2	2.6	ppb		
12000-D2-DF	Drinking Fountain in Classroom D-2	6.2	ppb		
12000-D1-S	Sink in Classroom D-1	7.0	ppb		
12000-D1-DF	Drinking Fountain in Classroom D-1	5.4	ppb		
12000-M152-SWB	Sink with Bubbler in Music Room M152	12.4	ppb		
12000-C4-S	Sink in Classroom C-4	2.6	ppb		
12000-C4-DF	Drinking Fountain in Classroom C-4	49.5	ppb	11.6	ppb
12000-C3-S	Sink in Classroom C-3	2.8	ppb		
12000-C3-DF	Drinking Fountain in Classroom C-3	6.8	ppb		
12000-C2-S	Sink in Classroom C-2	5.5	ppb		
12000-C1-S	Sink in Classroom C-1	5.8	ppb		
12000-C1-DF	Drinking Fountain in Classroom C-1	3.9	ppb		
12000-M134H-DF	Hallway Drinking Fountain near Gym	0.5	ppb		
12000-B4-S	Sink in Classroom B-4	4.9	ppb		
12000-B4-DF	Drinking Fountain in Classroom B-4	5.9	ppb		
12000-B3-S	Sink in Classroom B-3	2.3	ppb		
12000-B3-DF	Drinking Fountain in Classroom B-3	6.9	ppb		
12000-B2-S	Sink in Classroom B-2	3.7	ppb		
12000-B2-DF	Drinking Fountain in Classroom B-2	4.8	ppb		
12000-B1-S	Sink in Classroom B-1	2.7	ppb		
12000-B1-DF	Drinking Fountain in Classroom B-1	6.0	ppb		
12000-B105-DFL	Hallway Drinking Fountain near Office/Left	7.4	ppb		
12000-B105-DFR	Hallway Drinking Fountain near Office/Right	5.2	ppb		
12000-A4-S	Sink in Kindergarten Classroom A-4	4.6	ppb		
12000-A4-DF	Drinking Fountain in Kindergarten Classroom A-4	7.1	ppb		
12000-A3-SWB	Sink with Bubbler in Classroom A-3	3.2	ppb		
12000-A2-S	Sink in Classroom A-2	1.2	ppb		
12000-A2-DF	Drinking Fountain in Classroom A-2	4.2	ppb		
12000-A1-S	Sink in Classroom A-1	1.7	ppb		
12000-A1-DF	Drinking Fountain in Classroom A-1	3.5	ppb		
12000-A0-S	Sink in Classroom A-0	1.4	ppb		
12000-M111-S	Sink in Teacher's Lounge	1.6	ppb		
12000-R2-S	Sink in Room R-2	3.8	ppb		
12000-R1-S	Sink in Room R-1	2.0	ppb		
12000-R1-204-DF	Drinking Fountain in Temp R1-204	0.8	ppb		
12000-R1-170-DF	Drinking Fountain in Temp R1-170	6.1	ppb		
12000-REC-063-DF	Drinking Fountain in Temp REC-063	0.5	ppb		
12000-REC-108-S1	Sink in Temp REC-108	0.4	ppb		
12000-REC-108-S2	Sink in Temp REC-108	5.8	ppb		
12000-R1-30-S1	Sink in Temp R1-30	4.3	ppb		
12000-R1-30-S2	Sink in Temp R1-30	2.8	ppb		

\*\* Resampling results after elevated fixtures were removed and replaced.