

Foothills Elementary School - Sampled 6/23/16			
CustomerSampleNumber	Description	Lead Result	Units
14700-105-S	Sink in Cafeteria	36.1	ppb
14700-105-SWB	Sink with Bubblers in Cafeteria	11.1	ppb
14700-101-S1	Food Service Sink-Prep Sink	13.8	ppb
14700-101-S2	Food Service Sink-Rinse	5.6	ppb
14700-101-S3	Food Service Sink-Wash	2.3	ppb
14700-101-S4	Food Service Sink-Hand Sink	1.4	ppb
14700-109H-S	Sink in Hallway near Cafeteria	1.5	ppb
14700-109H-DF	Hallway Drinking Fountain near Cafeteria	6.1	ppb
147-001-S	Sink in Kindergarten Classroom 001	9.3	ppb
14700-001-SWB	Sink with Bubblers in Kindergarten Classroom 001	2.6	ppb
14700-003-S	Sink in Classroom 003	1.1	ppb
14700-003-SWB	Sink with Bubblers in Classroom 003	4.0	ppb
14700-114H-S	Sink in Hallway near Library	4.5	ppb
14700-114H-SWB	Sink with Bubblers in Hallway near Library	1.2	ppb
14700-159H-DF	Hallway Drinking Fountain near Planning Room 156	0.1	ppb
14700-007-S	Sink in Classroom 007	6.5	ppb
14700-008-S	Sink in Classroom 008	9.6	ppb
14700-009-S	Sink in Classroom 009	7.0	ppb
14700-010-S	Sink in Classroom 010	10.3	ppb
14700-011-S	Sink in Classroom 011	9.4	ppb
14700-012-S	Sink in Classroom 012	10.8	ppb
14700-013-S	Sink in Classroom 013	9.6	ppb
14700-014-S	Sink in Classroom 014	13.4	ppb
14700-015-S	Sink in Classroom 015	12.0	ppb
14700-016-S	Sink in Classroom 016	15.2	ppb
14700-177H-DF	Hallway Drinking Fountain near Classroom 016	<0.1 *	ppb
14700-172H-DF	Hallway Drinking Fountain near Classroom 017	0.1	ppb
14700-018-SWB	Sink with Bubblers in Classroom 018	2.3	ppb
14700-018-S	Sink in Classroom 018	8.9	ppb
14700-017-S	Sink in Room 017	12.7	ppb
14700-017-SWB	Sink with Bubblers in Room 017	20.1	ppb
14700-019-S1	Art Room Sink	15.9	ppb
14700-019-S2	Art Room Sink	4.7	ppb
14700-126H-DF	Hallway Drinking Fountain near Gym Storage Area	6.7	ppb
14700-136-S	Sink in Teacher's Lounge	1.8	ppb
14700-153X-SWB	Sink with Bubblers in Library Workroom	69.9	ppb
14700-142-S	Sink in Clinic	5.9	ppb
14700-142-SWB	Sink with Bubblers in Clinic	3.5	ppb
14700-REC-137-DF	Drinking Fountain in Temp REC-137	7.8	ppb
14700-R1-068-DF	Drinking Fountain in Temp R1-068	2.9	ppb
14700-R1-013-DF	Drinking Fountain in Temp R1-013	1.6	ppb

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.