

Foster Elementary School - Sampled 6/9/16				Resampled** 11/17/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
15000-103-S	Sink in Clinic	3.1	ppb		
15000-106H-DFL	Hallway Drinking Fountain/Left- across from Room 9	3.1	ppb		
15000-106H-DFR	Hallway Drinking Fountain/Right- across from Room 9	2.4	ppb		
15000-001-SWB	Sink with Bubblers in Classroom 1	5.4	ppb		
15000-002-SWB	Sink with Bubblers in Classroom 2	2.7	ppb		
15000-003-SWB	Sink with Bubblers in Classroom 3	3.4	ppb		
15000-004-SWB	Sink with Bubblers in Classroom 4	5.5	ppb		
15000-005-SWB	Sink with Bubblers in Classroom 5	7.0	ppb		
15000-006-SWB	Sink with Bubblers in Classroom 6	1.3	ppb		
15000-007-SWB	Sink with Bubblers in Classroom 7	3.6	ppb		
15000-008-SWB	Sink with Bubblers in Classroom 8	3.3	ppb		
15000-009-SWB	Sink with Bubblers in Classroom 9	1.7	ppb		
15000-118-DFL	Drinking Fountain in Lobby outside Main Office/Left	0.2	ppb		
15000-118-DFR	Drinking Fountain in Lobby outside Main Office/Right	0.1	ppb		
15000-124-SWB1	Sink with Bubblers in Art Room	4.6	ppb		
15000-124-SWB2	Sink with Bubblers in Art Room	5.4	ppb		
15000-128-S1	Food Service Sink	7.7	ppb		
15000-128-S2	Food Service Sink	7.8	ppb		
15000-128-S3	Food Service Sink	15.8	ppb	6.1	ppb
15000-128-S4	Food Service Sink	11.1	ppb		
15000-128-S5	Food Service Sink	8.1	ppb		
15000-128-S6	Food Service Sink	12.4	ppb		
15000-133-DF	Drinking Fountain in Cafeteria	0.5	ppb		
15000-016-SWB	Sink with Bubblers in Classroom 16	12.6	ppb		
15000-016H-DFL	Drinking Fountain in Hallway near Room 16/Left	7.0	ppb		
15000-016H-DFR	Drinking Fountain in Hallway near Room 16/Right	4.4	ppb		
15000-017-SWB	Sink with Bubblers in Classroom 17	3.1	ppb		
15000-018-SWB	Sink with Bubblers in Classroom 18	1.6	ppb		
15000-019-SWB	Sink with Bubblers in Classroom 19	1.8	ppb		
15000-149-SWB	Sink with Bubblers in Assistant Principal's Office	13.8	ppb		
15000-150-S	Sink in Teacher's Lounge	2.2	ppb		
15000-010-SWB	Sink with Bubblers in Kindergarten Classroom 10	0.7	ppb		
15000-011-SWB	Sink with Bubblers in Kindergarten Classroom 11	0.8	ppb		
15000-012-SWB	Sink with Bubblers in Classroom 12	0.7	ppb		
15000-013-SWB	Sink with Bubblers in Classroom 13	66.4	ppb	1.6	ppb
15000-155-SWB	Sink with Bubblers in Music Room	12.6	ppb		
15000-161-SWB	Sink with Bubblers in Kindergarten Classroom 161	0.2	ppb		
15000-X103-S	Sink in Library Workroom	1.5	ppb		

\*\* Resampling results after elevated fixtures were removed and replaced.