

Fremont Elementary School - Sampled 7/15/16			
CustomerSampleNumber	Description	Lead Result	Units
16000-041-S	Sink in Library	36.0	ppb
16000-041-SWB	Sink with Bubbler in Library	14.8	ppb
16000-039-S	Sink in Classroom 039	38.9	ppb
16000-039-SWB	Sink with Bubbler in Classroom 039	24.5	ppb
16000-037-S	Sink in Classroom 037	149.7	ppb
16000-037-SWB	Sink with Bubbler in Classroom 037	10.2	ppb
16000-140H-DFL	Hallway Drinking Fountain across from Classroom 034/Left	13.2	ppb
16000-140H-DFR	Hallway Drinking Fountain across from Classroom 034/Right	8.1	ppb
16000-036-SWB	Sink with Bubbler in Classroom 036	5.9	ppb
16000-036-S	Sink in Classroom 036	72.3	ppb
16000-038-S	Sink in Classroom 038	155.3	ppb
16000-038-SWB	Sink with Bubbler in Classroom 038	8.0	ppb
16000-030-S1	Food Service Sink-Sprayer	4.1	ppb
16000-030-S2	Food Service Sink-Wash	12.8	ppb
16000-030-S3	Food Service Sink-Food Prep	8.0	ppb
16000-030-S4	Food Service Sink-Hand Sink	9.5	ppb
16000-002-S	Sink in Clinic	0.5	ppb
16000-006-S	Sink in Classroom 006	6.9	ppb
16000-006-DF	Drinking Fountain in Classroom 006	9.3	ppb
16000-008-S	Sink in Classroom 008	14.9	ppb
16000-008-DF	Drinking Fountain in Classroom 008	7.8	ppb
16000-113H-DFL	Hallway Drinking Fountain across from Classroom 009/Left	3.8	ppb
16000-113H-DFR	Hallway Drinking Fountain across from Classroom 009/Right	3.7	ppb
16000-010-S1	Sink in Kindergarten Classroom 010	46.7	ppb
16000-010-SWB1	Sink with Bubbler in Kindergarten Classroom 010	10.9	ppb
16000-010-S2	Sink in Kindergarten Classroom 010	136.0	ppb
16000-010-SWB2	Sink with Bubbler in Kindergarten Classroom 010	20.8	ppb
16000-015-SWB	Sink with Bubbler in Kindergarten Classroom 015	8.3	ppb
16000-015-S	Sink in Kindergarten Classroom 015	65.6	ppb
16000-013-S	Sink in Classroom 013	4.9	ppb
16000-013-SWB	Sink with Bubbler in Classroom 013	6.0	ppb
16000-009-DF	Drinking Fountain in Classroom 009	14.8	ppb
16000-009-S	Sink in Classroom 009	28.6	ppb
16000-007-DF	Drinking Fountain in Classroom 007	6.6	ppb
16000-007-S	Sink in Classroom 007	16.0	ppb
16000-005-DF	Drinking Fountain in Teacher's Lounge	18.4	ppb
16000-005-S	Sink in Teacher's Lounge	3.2	ppb
16000-026-DF	Drinking Fountain in Classroom 026	11.0	ppb
16000-025-DF	Drinking Fountain in Classroom 025	8.4	ppb
16000-023-DF	Drinking Fountain in Classroom 023	8.9	ppb
16000-REC-059-DF	Drinking Fountain in TEMP REC-059	1.3	ppb
16000-REC-069-DF	Drinking Fountain in TEMP REC-069	0.7	ppb
16000-REC-058-DF	Drinking Fountain in TEMP REC-058	1.2	ppb