

Glennon Heights Elementary School - Sampled 6/28/16			
CustomerSampleNumber	Description	Lead Result	Units
18000-016H-DF	Hallway Drinking Fountain near Clinic	0.1	ppb
18000-028-S	Sink in Clinic	0.3	ppb
18000-057-SWB	Sink with Bubblers in Kindergarten Classroom 057	1.7	ppb
18000-054-S	Art Room Sink	2.8	ppb
18000-051H-DFL	Hallway Drinking Fountain near Classroom 047/Left	1.9	ppb
18000-051H-DFR	Hallway Drinking Fountain near Classroom 047/Right	9.3	ppb
18000-088H-DFL	Hallway Drinking Fountain near Classroom 067/Left	5.5	ppb
18000-088H-DFR	Hallway Drinking Fountain near Classroom 067/Right	2.5	ppb
18000-084-SWB	Sink with Bubblers in Classroom 084	1.0	ppb
18000-083-SWB	Sink with Bubblers in Classroom 083	2.5	ppb
18000-079-SWB	Sink with Bubblers in Classroom 079	4.1	ppb
18000-078-SWB	Sink with Bubblers in Classroom 078	14.5	ppb
18000-073-SWB	Sink with Bubblers in Classroom 073	0.6	ppb
18000-072-SWB	Sink with Bubblers in Classroom 072	0.8	ppb
18000-068-SWB	Sink with Bubblers in Classroom 068	6.0	ppb
18000-067-SWB	Sink with Bubblers in Classroom 067	4.5	ppb
18000-042-S	Sink in Teacher's Lounge	1.3	ppb
18000-041-SWB	Sink with Bubblers in Classroom 041	1.7	ppb
18000-037-SWB	Sink with Bubblers in Classroom 037	1.7	ppb
18000-035-SWB	Sink with Bubblers in Classroom 035	1.0	ppb
18000-032-SWB	Sink with Bubblers in Classroom 032	2.0	ppb
18000-031-SWB	Sink with Bubblers in Kindergarten Classroom 031	1.8	ppb
18000-R1-230-S1	Sink in Temp R1-230	1.0	ppb
18000-R1-230-S2	Sink in Temp R1-230	1.3	ppb
18000-R1-219-S1	Sink in Temp R1-219	1.7	ppb
18000-R1-219-S2	Sink in Temp R1-219	12.6	ppb
18000-R1-221-S1	Sink in Temp R1-221	0.5	ppb
18000-R1-221-S2	Sink in Temp R1-221	4.3	ppb
18000-R1-231-S	Sink in Temp R1-231	1.0	ppb
18000-R1-239-DF	Drinking Fountain in Temp R1-239	1.7	ppb
18000-005-S1	Food Service-Hand Sink	4.5	ppb
18000-005-S2	Food Service-Rinse/Sanitize Sink	6.4	ppb
18000-005-S3	Food Service-Wash/Rinse Sink	3.1	ppb