

Golden High School - Sampled 10/18/16			
CustomerSampleNumber	Description	Lead Result	Unit
75000-C1-04H-DFL	Hallway Drinking Fountain across from Classroom C105/Left	<0.1 *	ppb
75000-C1-04H-DFR	Hallway Drinking Fountain across from Classroom C105/Right	<0.1 *	ppb
75000-100M-S	Sink in Planning Room 100M	0.3	ppb
75000-100F-S	Sink in Clinic	1.4	ppb
75000-111-S	Sink in Office 111	0.3	ppb
75000-114D-S	Sink in Library Work Room	0.2	ppb
75000-115-S	Sink in Office 115	0.6	ppb
75000-120-S	Sink in Consumer Science Lab 120	0.6	ppb
75000-331H-DFL	Hallway Drinking Fountain across from Classroom 125/Left	0.2	ppb
75000-331H-DFR	Hallway Drinking Fountain across from Classroom 125/Right	<0.1 *	ppb
75000-123-S1	Sink in Kitchen Classroom 123	0.3	ppb
75000-123-S2	Sink in Kitchen Classroom 123	0.5	ppb
75000-123-S3	Sink in Kitchen Classroom 123	0.2	ppb
75000-123-S4	Sink in Kitchen Classroom 123	0.4	ppb
75000-123-S5	Sink in Kitchen Classroom 123	0.3	ppb
75000-123-S6	Sink in Kitchen Classroom 123	0.3	ppb
75000-123-S7	Sink in Kitchen Classroom 123	0.4	ppb
75000-127-S	Sink in Office 127	0.5	ppb
75000-206-S	Sink in Conference Room 206	2.1	ppb
75000-C2-01H-DFL	Hallway Drinking Fountain across from Classroom 210/Left	<0.1 *	ppb
75000-C2-01H-DFR	Hallway Drinking Fountain across from Classroom 210/Right	<0.1 *	ppb
75000-214-S	Sink in Office 214	0.4	ppb
75000-C2-02-S	Sink in Counseling Offices Hallway	0.3	ppb
75000-333H-DFL	Hallway Drinking Fountain across from Laboratory 233/Left	<0.1 *	ppb
75000-333H-DFR	Hallway Drinking Fountain across from Laboratory 233/Right	<0.1 *	ppb
75000-221-S	Sink in Office 221	0.6	ppb
75000-236-S	Sink in Office 236	0.3	ppb
75000-226-S1	Sink in Science Prep Room 226	2.7	ppb
75000-226-S2	Sink in Science Prep Room 226	0.3	ppb
75000-223-S	Sink in Conference Room 223	0.3	ppb
75000-151H-DFL	Hallway Drinking Fountain outside of Locker Room/Left	<0.1 *	ppb
75000-151H-DFR	Hallway Drinking Fountain outside of Locker Room/Right	<0.1 *	ppb
75000-148-DFL	Drinking Fountain in Dance Room 148/Left	<0.1 *	ppb
75000-148-DFR	Drinking Fountain in Dance Room 148/Right	<0.1 *	ppb
75000-153H-DFL	Hallway Drinking Fountain outside of Locker Room/Left	<0.1 *	ppb
75000-153H-DFR	Hallway Drinking Fountain outside of Locker Room/Right	<0.1 *	ppb
75000-150-DFL	Drinking Fountain inside of Small Gym/Left	<0.1 *	ppb
75000-150-DFR	Drinking Fountain inside of Small Gym/Right	<0.1 *	ppb
75000-145-DFL	Drinking Fountain inside of Large Gym/Left	<0.1 *	ppb
75000-145-DFR	Drinking Fountain inside of Large Gym/Right	<0.1 *	ppb
75000-146-IM	Ice Machine in Training Room 146	<0.1 *	ppb
75000-146-S	Sink in Training Room 146	0.2	ppb
75000-143H-DFL	Hallway Drinking Fountain outside of Locker Rooms/Left	<0.1 *	ppb
75000-143H-DFR	Hallway Drinking Fountain outside of Locker Rooms/Right	<0.1 *	ppb
75000-144AH-DFL	Hallway Drinking Fountain outside of Locker Rooms/Left	<0.1 *	ppb

75000-144AH-DFR	Hallway Drinking Fountain outside of Locker Rooms/Right	<0.1 *	ppb
75000-139-S	Sink in Store	0.9	ppb
75000-139-IM	Ice Machine in Store	1.2	ppb
75000-C1-10H-DFL	Hallway Drinking Fountain across from Large Gym/Left	<0.1 *	ppb
75000-C1-10H-DFR	Hallway Drinking Fountain across from Large Gym/Right	<0.1 *	ppb
75000-135-S	Sink in Vocal Room 135	0.2	ppb
75000-C1-08H-DFL	Hallway Drinking Fountain in Cafeteria/Left	<0.1 *	ppb
75000-C1-08H-DFR	Hallway Drinking Fountain in Cafeteria/Right	<0.1 *	ppb
75000-138-S1	Food Service Sink-Hand Sink	2.6	ppb
75000-138-S2	Food Service Sink-Food Prep	0.2	ppb
75000-138-S3	Food Service Sink-Food Prep Sprayer	2.5	ppb
75000-138-S4	Food Service Sink-Hand Sink	0.7	ppb
75000-138-S5	Food Service Sink-Hand Sink	1.0	ppb
75000-138-S6	Food Service Sink-Sprayer	3.3	ppb
75000-138-S7	Food Service Sink-Wash/Rinse	3.4	ppb
75000-138-S8	Food Service Sink-Rinse/Sanitize	4.8	ppb
75000-138-S9	Food Service Sink-Hand Sink	5.1	ppb
75000-132-S	Sink in Instrument/Band Room 132	0.3	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			