

Green Gables Elementary School - Sampled 7/8/16			
CustomerSampleNumber	Description	Lead Result	Units
18300-122-S	Sink in Clinic	8.0	ppb
18300-121H-DF	Hallway Drinking Fountain near Principal's Office	8.2	ppb
18300-172H-S	Sink in Hallway by Classroom 2	2.6	ppb
18300-172H-SWB	Sink with Bubbler in Hallway near Classroom 2	2.1	ppb
18300-105H-DF	Hallway Drinking Fountain near Girls Restroom near Room 3	2.2	ppb
18300-174H-S	Sink in Hallway by Classroom 4	2.0	ppb
18300-174H-SWB	Sink with Bubbler in Hallway by Classroom 4	1.4	ppb
18300-106H-DF	Hallway Drinking Fountain near Boys Restroom near Room 3	9.3	ppb
18300-112H-DF	Hallway Drinking Fountain near Boys Restroom near Room 11	2.0	ppb
18300-180H-S	Sink in Hallway across from Classroom 12	3.3	ppb
18300-180H-SWB	Sink with Bubbler in Hallway across from Classroom 12	1.8	ppb
18300-176H-S	Sink in Hallway near Classroom 5/6	2.4	ppb
18300-176H-SWB	Sink with Bubbler in Hallway near Classroom 5/6	2.5	ppb
18300-114H-DF	Hallway Drinking Fountain near Girls Restroom near Room 11	180.4	ppb
18300-179H-S	Sink in Hallway near Classroom 9	0.6	ppb
18300-179H-SWB	Sink with Bubbler in Hallway near Classroom 9	0.6	ppb
18300-138-S1	Art Room Sink	5.7	ppb
18300-138-S2	Art Room Sink	1.7	ppb
18300-170H-DF	Hallway Drinking Fountain near Gym	5.5	ppb
18300-130-S	Sink in Teacher's Lounge	0.4	ppb
18300-153-S1	Food Service Sink-Hand Sink	4.2	ppb
18300-153-S4	Food Service Sink-Wash/Rinse	27.6	ppb
18300-153-S3	Food Service Sink-Sanitize	15.4	ppb
18300-153-S5	Food Service Sink-Food Prep	20.8	ppb
18300-151H-DF	Hallway Drinking Fountain outside of Cafeteria	4.4	ppb
18300-151-S	Sink in Cafeteria	3.8	ppb
18300-151-SWB	Sink with Bubbler in Cafeteria	5.9	ppb
18300-150-S1	Sink in Multipurpose Room	13.3	ppb
18300-150-SWB1	Sink with Bubbler in Multipurpose Room	6.4	ppb
18300-150-S2	Sink in Multipurpose Room	4.4	ppb
18300-150-SWB2	Sink in with Bubbler in Multipurpose Room	4.9	ppb
18300-R1-014-DF	Drinking Fountain in Temporary Classroom R1-014	3.7	ppb
18300-R1-012-DF	Drinking Fountain in Temporary Classroom R1-012	8.3	ppb
18300-153-S2	Food Service Sink-Sprayer	10.9	ppb