

Green Mountain Elementary School - Sampled 6/16/16			
CustomerSampleNumber	Description	Lead Result	Units
18500-74H-SWB	Hallway Sink with Bubbler near Classroom 74	0.5	ppb
18500-96H-SWB	Hallway Sink with Bubbler near Classroom 96	0.9	ppb
18500-96H-S	Hallway Sink near Classroom 96	3.7	ppb
18500-78H-SWB	Hallway Sink with Bubbler near Classroom 78	0.8	ppb
18500-87-SWB	Hallway Sink with Bubbler near Classroom 87	0.9	ppb
18500-79H-DFR	Hallway Drinking Fountain near Classroom 78/Left	3.5	ppb
18500-79-DFL	Hallway Drinking Fountain near Classroom 78/Right	4.5	ppb
18500-12-S	Sink in Teacher's Lounge	1.1	ppb
18500-211-S	Sink in Clinic	2.1	ppb
18500-18-SWB	Sink with Bubbler in Kindergarten Classroom 18	1.6	ppb
18500-18-S	Sink in Kindergarten Classroom 18	9.9	ppb
18500-21-S	Sink in Kindergarten Classroom 21	4.1	ppb
18500-21-SWB	Sink with Bubbler in Kindergarten Classroom 21	6.9	ppb
18500-20-SWB	Sink with Bubbler in Classroom 20	2.7	ppb
18500-20-S	Sink in Classroom 20	2.1	ppb
18500-19-S	Sink in Classroom 19	6.2	ppb
18500-19-SWB	Sink with Bubbler in Classroom 19	3.2	ppb
18500-90-S	Sink in Library Workroom	2.6	ppb
18500-40-S2	Food Service Sink - Wash/Rinse/Sanitize	5.0	ppb
18500-40-S1	Food Service Sink - Hose Connection Spigot	32.0	ppb
18500-55H-DF	Hallway Drinking Fountain near Gym	0.5	ppb
18500-51-S	Sink in Classroom 51	3.9	ppb
18500-51-SWB	Sink with Bubbler in Classroom 51	2.2	ppb
18500-52-S	Sink in Classroom 52	20.6	ppb
18500-52-SWB	Sink with Bubbler in Classroom 52	4.2	ppb
18500-47-S1	Art Room Sink	5.0	ppb
18500-47-S2	Art Room Sink	2.2	ppb
18500-R1-086-DF	Drinking Fountain in Temp R1-086	1.5	ppb
18500-R1-046-SWB	Sink with Bubbler in Temp R1-046	11.2	ppb
18500-046-S	Sink in Temp R1-046	9.3	ppb
18500-40-S3	Food Service Sink - Hand Sink	9.1	ppb