

Hutchinson Elementary School - Sampled 6/14/16			
CustomerSampleNumber	Description	Lead Result	Units
19200-3A-S	Sink in Classroom 3A	8.6	ppb
19200-173H-SWB	Hallway Sink with Bubbler near Classroom 15	4.0	ppb
19200-180H-SWB	Hallway Sink with Bubbler near Classroom 12	4.2	ppb
19200-E141-S1	Food Service Sink	6.3	ppb
19200-E141-S2	Food Service Sink	4.9	ppb
19200-E141-S3	Food Service Sink	11.6	ppb
19200-E141-S4	Food Service Sink	6.7	ppb
19200-154H-SWB	Hallway Sink with Bubbler near Library/Right	2.8	ppb
19200-153H-SWB	Hallway Sink with Bubbler near Library/Left	2.3	ppb
19200-17-S1	Art Room Sink	6.0	ppb
19200-17-S2	Art Room Sink	5.6	ppb
19200-18-S1	Sink in Classroom 18	3.5	ppb
19200-18-S2	Sink in Classroom 18	4.8	ppb
19200-100X-S	Sink in Teacher's Lounge	0.5	ppb
19200-117B-S	Sink in Small Restroom near Teacher's Lounge	3.3	ppb
19200-130-S	Sink in Clinic	5.6	ppb
19200-143H-SWB	Hallway Sink with Bubbler Across from Office	5.9	ppb
19200-1-SWB2	Sink with Bubbler in Kindergarten Classroom 2	3.4	ppb
19200-1-SWB1	Sink with Bubbler in Kindergarten Classroom 1	7.9	ppb
19200-154-S	Sink in Restroom near Library	11.9	ppb