

Irwin Preschool Sampled - 7/28/16			
CustomerSampleNumber	Description	Lead Result	Units
19695-106X-S	Sink in Clinic	13.9	ppb
19695-106H-DFL	Main Hallway Drinking Fountain/Left	0.3	ppb
19695-106H-DFR	Main Hallway Drinking Fountain/Right	0.5	ppb
19695-108-S	Sink in Teacher's Lounge	3.0	ppb
19695-107X-S	Sink in Work Room 107X	2.0	ppb