

Kyffin Elementary School - Sampled 6/23/16			
CustomerSampleNumber	Description	Lead Result	Units
22400-8H-DF	Drinking Fountain in Hallway near Front Entrance	1.0	ppb
22400-8-S1	Sink in Kindergarten Classroom 8	1.4	ppb
22400-197H-S	Sink in Hallway across from Kindergarten Classroom 9	6.9	ppb
22400-197-SWB	Sink with Bubblers in Hallway across from Kindergarten Classroom 9	1.1	ppb
22400-200H-SWB	Sink with Bubblers in Hallway across from Classroom 20	0.6	ppb
22400-200H-S	Sink in Hallway across from Classroom 20	1.4	ppb
22400-202H-S	Sink in Hallway across from Classroom 18	0.5	ppb
22400-202-SWB	Sink with Bubblers across from Classroom 18	0.9	ppb
22400-181-S	Sink in Library Workroom	11.3	ppb
22400-181-SWB	Sink with Bubblers in Library Workroom	34.5	ppb
22400-204H-SWB	Sink with Bubblers in Hallway across from Kitchen	1.9	ppb
22400-204H-S	Sink in Hallway across from Kitchen	6.6	ppb
22400-203H-S	Sink in Hallway across from Kitchen	4.5	ppb
22400-203H-SWB	Sink with Bubblers in Hallway across from Kitchen	0.5	ppb
22400-E02-S1	Food Service Sink-Hand Sink	3.2	ppb
22400-E02-S2	Food Service Sink-Rinse/Sanitize	13.0	ppb
22400-E02-S3	Food Service Sink-Wash	13.1	ppb
22400-E02-S4	Food Service Sink-Food Prep	9.4	ppb
22400-E02-S5	Food Service Sink-Food Prep	93.4	ppb
22400-E03-S1	Art Room Sink	2.0	ppb
22400-E03-S2	Art Room Sink	1.5	ppb
22400-E05XH-DF	Hallway Drinking Fountain between Art and Music Rooms	0.9	ppb
22400-A01-DF	Drinking Fountain in Cafeteria	0.3	ppb
22400-A01-S	Sink in Cafeteria	2.1	ppb
22400-33H-DF	Hallway Drinking Fountain near Classroom 33	0.5	ppb
22400-34-SWB	Sink with Bubblers in Classroom 34	2.0	ppb
22400-34-S	Sink in Classroom 34	4.0	ppb
22400-35-S	Sink in Classroom 35	1.6	ppb
22400-35-SWB	Sink with Bubblers in Classroom 35	2.0	ppb
22400-B11H-DFL	Hallway Drinking Fountain near Classroom 35/Left	0.3	ppb
22400-B11H-DFR	Hallway Drinking Fountain near Classroom 35/Right	0.3	ppb
22400-31-S	Sink in Classroom 31	1.6	ppb
22400-31-SWB	Sink with Bubblers in Classroom 31	2.7	ppb
22400-136-S	Sink in Clinic	5.1	ppb
22400-136-SWB	Sink with Bubblers in Clinic	1.0	ppb
22400-155-S	Sink in Teacher's Lounge	1.4	ppb
22400-5-S1	Sink in Workroom next to Kindergarten Classroom 4	0.3	ppb
22400-5-SWB1	Sink with Bubblers in Workroom next to Kindergarten Classroom 4	0.6	ppb
22400-5-S2	Sink in Workroom next to Kindergarten Classroom 4	0.5	ppb
22400-5-SWB2	Sink with Bubblers in Workroom next to Kindergarten Classroom 4	0.6	ppb
22400-RE-013-DF	Drinking Fountain in Temp RE-013	1.2	ppb
22400-REC-133-DF	Drinking Fountain in Temp REC-133	1.5	ppb
22400-8-S2	Sink in Kindergarten Classroom 8	1.5	ppb
22400-30-S	Sink in Room 30	0.5	ppb