

Little Elementary School - Sampled 7/26/16			
CustomerSampleNumber	Description	Lead Result	Units
23500-REC-067-DF	Drinking Fountain in TEMP REC-067	0.9	ppb
23500-REC-114-DF	Drinking Fountain in TEMP REC-114	0.3	ppb
23500-135H-DF	Hallway Drinking Fountain Outside of Art Room	11.4	ppb
23500-101-S	Sink in Kindergarten Classroom 101	6.9	ppb
23500-101-SWB	Sink with Bubbler in Kindergarten Classroom 101	23.1	ppb
23500-141-S	Sink in Kindergarten Classroom 141	13.1	ppb
23500-141-SWB	Sink with Bubbler in Kindergarten Classroom 141	3.5	ppb
23500-140H-S	Hallway Sink across from Main Office	5.1	ppb
23500-140H-SWB	Hallway Sink with Bubbler across from Main Office	4.5	ppb
23500-131AX-S	Sink in Clinic	7.2	ppb
23500-131AX-SWB	Sink with Bubbler in Clinic	3.2	ppb
23500-129-S	Sink in Planning Room 129	24.3	ppb
23500-105-S	Sink in Teacher's Lounge	1.4	ppb
23500-165-S1	Food Service Sink-Hand Sink	327.8	ppb
23500-165-S2	Food Service Sink-Dish Wash/Sprayer	18.7	ppb
23500-165-S3	Food Service Sink-Wash/Rinse	7.8	ppb
23500-165-S4	Food Service Sink-Rinse/Sanitize	16.4	ppb
23500-165-S5	Food Service Sink-Food Prep	8.9	ppb
23500-165-S6	Food Service Sink-Food Prep/Hose Connector Spigot	23.8	ppb
23500-176H-S1	Hallway Sink Outside of Kitchen	3.3	ppb
23500-176H-SWB1	Hallway Sink with Bubbler Outside of Kitchen	2.2	ppb
23500-176H-S2	Hallway Sink Outside of Kitchen	5.1	ppb
23500-176H-SWB2	Hallway Sink with Bubbler Outside of Kitchen	3.0	ppb
23500-182A-S	Sink in Classroom 182A	2.6	ppb
23500-182A-SWB	Sink with Bubbler in Classroom 182A	1.6	ppb
23500-167-S	Sink in Classroom 167	0.6	ppb
23500-167-SWB	Sink with Bubbler in Classroom 167	0.3	ppb
23500-168-S	Sink in Classroom 168	1.0	ppb
23500-168-SWB	Sink with Bubbler in Classroom 168	0.3	ppb
23500-124-S	Sink in Classroom 124	0.5	ppb
23500-124-SWB	Sink with Bubbler in Classroom 124	0.8	ppb
23500-137H-S	Hallway Sink across from Classroom 169	4.4	ppb
23500-137H-SWB	Hallway Sink with Bubbler across from Classroom 169	7.4	ppb
23500-111-S	Sink in Classroom 111	1.1	ppb
23500-113-S	Sink in Classroom 113	1.4	ppb
23500-177-S	Sink in Classroom 177	1.0	ppb
23500-174H-S	Hallway Sink across from Classroom 169B	4.6	ppb
23500-174H-SWB	Hallway Sink with Bubbler across from Classroom 169B	7.8	ppb
23500-172-S	Sink in Classroom 172	0.7	ppb
23500-138-S1	Art Room Sink	8.7	ppb
23500-138-S2	Art Room Sink	5.7	ppb
23500-147C-S	Sink in Library Work Room	21.5	ppb
23500-149-S	Sink in Library Work Room	35.9	ppb