

Lukas Elementary School - 7/12/16			
CustomerSampleNumber	Description	Lead Result	Units
23800-110-S	Sink in Clinic	0.3	ppb
23800-123H-DF	Hallway Drinking Fountain by Music Room	0.3	ppb
23800-122-S1	Food Service Sink-Wash/Rinse	2.0	ppb
23800-122-S2	Food Service Sink-Rinse/Sanitize	7.4	ppb
23800-122-S3	Food Service Sink-Sprayer	2.1	ppb
23800-122-S4	Food Service Sink-Hand Sink	1.2	ppb
23800-126-S1	Art Room Sink	1.9	ppb
23800-126-S2	Art Room Sink	1.5	ppb
23800-126-S3	Art Room Sink	1.0	ppb
23800-126-S4	Art Room Sink	0.8	ppb
23800-126-S5	Art Room Sink	1.0	ppb
23800-126-S6	Art Room Sink	1.2	ppb
23800-126-S7	Art Room Sink	0.8	ppb
23800-126-S8	Art Room Sink	0.8	ppb
23800-21-S	Sink in Classroom 21	0.6	ppb
23800-20-S	Sink in Classroom 20	0.6	ppb
23800-19-S	Sink in Classroom 19	0.6	ppb
23800-141H-DF	Hallway Drinking Fountain near Classroom 18	0.2	ppb
23800-18-S	Sink in Classroom 18	0.3	ppb
23800-16-S	Sink in Classroom 16	0.9	ppb
23800-15-S	Sink in Classroom 15	0.4	ppb
23800-148H-DF	Hallway Drinking Fountain near Classroom 15	0.7	ppb
23800-14-S	Sink in Classroom 14	0.4	ppb
23800-13-S	Sink in Classroom 13	0.4	ppb
23800-158H-DF	Hallway Drinking Fountain near Classroom 12	0.3	ppb
23800-12-S	Sink in Classroom 12	0.5	ppb
23800-10-S	Sink in Classroom 10	0.3	ppb
23800-157H-DF	Hallway Drinking Fountain near Classroom 10	0.2	ppb
23800-009-S	Sink in Classroom 009	0.3	ppb
23800-008-S	Sink in Classroom 008	0.2	ppb
23800-167-S	Sink in Library Work Room	2.2	ppb
23800-174H-DF	Hallway Drinking Fountain near Classroom 007	0.8	ppb
23800-007-S	Sink in Classroom 007	1.1	ppb
23800-006-S	Sink in Classroom 006	1.1	ppb
23800-004-S	Sink in Classroom 004	0.2	ppb
23800-181H-DF	Hallway Drinking Fountain near Classroom 003	0.2	ppb
23800-003-S	Sink in Classroom 003	0.2	ppb
23800-002-S	Sink in Classroom 002	1.2	ppb
23800-001-S	Sink in Classroom 001	0.3	ppb
23800-191-S	Sink in Teacher's Lounge	0.4	ppb
23800-195H-DFL	Hallway Drinking Fountain near Main Office/Left	0.2	ppb
23800-195H-DFR	Hallway Drinking Fountain near Main Office/Right	0.2	ppb
23800-K2-S	Sink in Kindergarten Classroom K2	0.5	ppb
23800-K1-S	Sink in Kindergarten Classroom K1	0.7	ppb