

Mandalay Middle School - Sampled 9/2/16			
CustomerSampleNumber	Description	Lead Result	Unit
67400-1050H-DF	Hallway Drinking Fountain near the Main Entrance	1.7	ppb
67400-101-S	Sink in Instrument/Band Room 101	2.4	ppb
67400-1044H-DF	Hallway Drinking Fountain near the Cafeteria	1.0	ppb
67400-1099H-DF	Hallway Drinking Fountain on the First Floor near the Elevator	0.4	ppb
67400-1091-DF	Drinking Fountain in the Girls Locker Room	4.8	ppb
67400-1082-DF	Drinking Fountain in the Boys Locker Room	5.7	ppb
67400-1090-S	Sink in Training Room 1090	84.4	ppb
67400-112-S1	Sink in Art Room 112/Left	2.9	ppb
67400-112-S2	Sink in Art Room 112/Right	4.6	ppb
67400-110-S1	Sink in Art Room 110/Left	16.8	ppb
67400-110-S2	Sink in Art Room 110/Right	56.3	ppb
67400-1059-S	Sink in Custodial Office	1.5	ppb
67400-106-S	Sink in Teachers' Lounge	17.2	ppb
67400-1031-S1	Food Service Sink - Wash/Rinse	7.0	ppb
67400-1031-S2	Food Service Sink - Rinse/Sanitize	1.4	ppb
67400-1031-S3	Food Service Sink - Food Prep	5.2	ppb
67400-1032-S	Food Service Sink - Hand Sink	5.3	ppb
67400-104-S1	Sink in Consumer Science Classroom 104	6.4	ppb
67400-104-S2	Sink in Consumer Science Classroom 104	5.3	ppb
67400-104-S3	Sink in Consumer Science Classroom 104	5.8	ppb
67400-104-S4	Sink in Consumer Science Classroom 104	42.3	ppb
67400-104-S5	Sink in Consumer Science Classroom 104	5.6	ppb
67400-104-S6	Sink in Consumer Science Classroom 104	2.3	ppb
67400-104-S7	Sink in Consumer Science Classroom 104	5.7	ppb
67400-102-S	Sink in Consumer Science Classroom 102	11.1	ppb
67400-102-SWB	Sink with Bubbler in Consumer Science Classroom 102	3.0	ppb
67400-1017-S	Sink in Clinic	3.2	ppb
67400-1010-S	Sink in Planning Room 1010 near Principal's Office	3.6	ppb
67400-249-S	Sink in Planning Room 249 near Library	5.8	ppb
67400-201-S1	Sink in Science Classroom 201	2.8	ppb
67400-201-S2	Sink in Science Classroom 201	10.3	ppb
67400-201-S3	Sink in Science Classroom 201	7.3	ppb
67400-201-S4	Sink in Science Classroom 201	2.3	ppb
67400-207-S1	Sink in Science Classroom 207	11.7	ppb
67400-207-S2	Sink in Science Classroom 207	19.1	ppb
67400-207-S3	Sink in Science Classroom 207	19.8	ppb
67400-207-S4	Sink in Science Classroom 207	13.3	ppb
67400-2042-S	Sink in Science Prep Room 2042	10.3	ppb
67400-209-S1	Sink in Science Classroom 209	12.8	ppb
67400-209-S2	Sink in Science Classroom 209	172.8	ppb
67400-209-S3	Sink in Science Classroom 209	13.8	ppb
67400-209-S4	Sink in Science Classroom 209	8.1	ppb
67400-211-S1	Sink in Science Classroom 211	10.4	ppb
67400-211-S2	Sink in Science Classroom 211	11.6	ppb
67400-211-S3	Sink in Science Classroom 211	6.8	ppb
67400-211-S4	Sink in Science Classroom 211	10.2	ppb

67400-213-S1	Sink in Science Classroom 213	5.8	ppb
67400-213-S2	Sink in Science Classroom 213	5.6	ppb
67400-213-S3	Sink in Science Classroom 213	33.3	ppb
67400-213-S4	Sink in Science Classroom 213	12.1	ppb
67400-209H-DF	Hallway Drinking Fountain near Science Classroom 209	0.6	ppb
67400-2035H-DF	Hallway Drinking Fountain near Restrooms across from Library	1.7	ppb
67400-224H-DF	Hallway Drinking Fountain on the Second Floor near the Elevator	0.3	ppb