

The Manning School - Sampled 8/2/16			
CustomerSampleNumber	Description	Lead Result	Units
67500-N100C-S	Sink in Clinic Restroom	0.9	ppb
67500-N100E-S	Sink in Workroom by Main Office Reception Area	1.7	ppb
67500-N104-S1	Sink in Art Room N104	2.7	ppb
67500-N104-S2	Sink in Art Room N104	3.3	ppb
67500-N104-S3	Sink in Art Room N104	0.9	ppb
67500-N104-S4	Sink in Art Room N104	1.5	ppb
67500-N106-S1	Sink in Sience Room N106	0.7	ppb
67500-N106-S2	Sink in Sience Room N106	9.6	ppb
67500-N106-S3	Sink in Sience Room N106	7.5	ppb
67500-N106-S4	Sink in Sience Room N106	5.5	ppb
67500-N108-S1	Sink in Science Room N108	0.6	ppb
67500-N108-S2	Sink in Science Room N108	3.2	ppb
67500-N108-S3	Sink in Science Room N108	1.2	ppb
67500-N108-S4	Sink in Science Room N108	2.7	ppb
67500-N152H-WBFS	Water Bottle Filling Station in Hallway near Room N107	0.4	ppb
67500-N152H-DF	Drinking Fountain in Hallway near Room N107	0.4	ppb
67500-N155-S	Sink in Conference Room N155	1.0	ppb
67500-S184H-DF	Drinking Fountain in Hallway across from Restrooms near Gym	0.3	ppb
67500-B10-S1	Sink in Science Room B10	4.8	ppb
67500-B10-S2	Sink in Science Room B10	2.1	ppb
67500-B10-S3	Sink in Science Room B10	2.4	ppb
67500-B10-S4	Sink in Science Room B10	0.6	ppb
67500-S145-S	Sink in Science Prep Room between Rooms B8 and B10	5.9	ppb
67500-B8-S1	Sink in Science Room B8 (by hallway wall on the left)	3.4	ppb
67500-B8-S2	Sink in Science Room B8 (by hallway wall on the right)	0.8	ppb
67500-B8-S3	Sink in Science Room B8 (by windows on the left)	25.6	ppb
67500-B8-S4	Sink in Science Room B8 (by windows on the right)	7.3	ppb
67500-S144H-WBFS	Water Bottle Filling Station in Hallway near Room B8	34.7	ppb
67500-S144H-DF	Drinking Fountain in Hallway near Room B8	17.0	ppb
67500-C1-DF	Drinking Fountain in the Cafeteria	0.1	ppb
67500-S106-S1	Food Services - Hand Sink	354.7	ppb
67500-S106-S2	Food Services - Sprayer	20.1	ppb
67500-S106-S3	Food Services - Wash/Rinse Sink	6.2	ppb
67500-S106-S4	Food Services - Rinse/Sanitize Sink	12.2	ppb
67500-S133H-WBFS	Water Bottle Filling Station in Hallway near the Choir Room	0.4	ppb
67500-S133H-DF	Drinking Fountain in the Hallway near the Choir Room	0.6	ppb
67500-S114-S	Sink in Teachers Lounge	1.3	ppb
67500-S123-SWB	Bubbler on the Sink in the Band Room	16.7	ppb
67500-S123-S	Sink in the Band Room	12.6	ppb