

Meiklejohn Elementary School - Sampled 11/2/16			
CustomerSampleNumber	Description	Lead Result	Unit
26500-1301-S	Sink in Kindergarten Classroom 1301	1.0	ppb
26500-1301-SWB	Sink with Bubbler in Kindergarten Classroom 1301	<0.1 *	ppb
26500-1305-S	Sink in Kindergarten Classroom 1305	2.1	ppb
26500-1305-SWB	Sink with Bubbler in Kindergarten Classroom 1305	<0.1 *	ppb
26500-1307-S	Sink in Kindergarten Classroom 1307	<0.1 *	ppb
26500-1307-SWB	Sink with Bubbler in Kindergarten Classroom 1307	1.6	ppb
26500-1310-S	Sink in Kindergarten Classroom 1310	0.7	ppb
26500-1310-SWB	Sink with Bubbler in Kindergarten Classroom 1310	0.3	ppb
26500-1401-S	Sink in Classroom 1401	<0.1 *	ppb
26500-1401-SWB	Sink with Bubbler in Classroom 1401	<0.1 *	ppb
26500-1403-S	Sink in Classroom 1403	0.6	ppb
26500-1403-SWB	Sink with Bubbler in Classroom 1403	<0.1 *	ppb
26500-1402-S	Sink in Classroom 1402	<0.1 *	ppb
26500-1402-SWB	Sink with Bubbler in Classroom 1402	<0.1 *	ppb
26500-1501-S	Sink in Classroom 1501	1.8	ppb
26500-1502-S	Sink in Classroom 1502	0.6	ppb
26500-1503-S	Sink in Pre-K Classroom 1503	<0.1 *	ppb
26500-1504-S	Sink in Pre-K Classroom 1504	0.2	ppb
26500-1505-S	Sink in Pre-K Classroom 1505	1.1	ppb
26500-1506-S	Sink in Office 1506	0.4	ppb
26500-499H-DFL	Hallway Drinking Fountain outside of Classroom 1502/Left	<0.1 *	ppb
26500-499H-DFR	Hallway Drinking Fountain outside of Classroom 1502/Right	<0.1 *	ppb
26500-1513-S	Sink in Classroom 1513	1.9	ppb
26500-1513-SWB	Sink with Bubbler in Classroom 1513	<0.1 *	ppb
26500-1514-S	Sink in Classroom 1514	0.6	ppb
26500-1406-S	Sink in Classroom 1406	1.9	ppb
26500-1012H-DFL	Hallway Drinking Fountain outside of Classroom 1401/Left	<0.1 *	ppb
26500-1012H-DFR	Hallway Drinking Fountain outside of Classroom 1401/Right	0.2	ppb
26500-1414-S	Sink in Classroom 1414	<0.1 *	ppb
26500-1415-S	Sink in Classroom 1415	0.6	ppb
26500-1315-S	Sink in Library Work Room	1.3	ppb
26500-1007H-DFL	Hallway Drinking Fountain across from Kindergarten Classroom 1301/Left	0.7	ppb
26500-1007H-DFR	Hallway Drinking Fountain across from Kindergarten Classroom 1301/Right	<0.1 *	ppb
26500-1201-S1	Sink in Instrument/Band Room	2.7	ppb
26500-1201-S2	Sink in Instrument/Band Room	4.1	ppb
26500-1204-S1	Sink in Art Room 1204	0.2	ppb
26500-1204-S2	Sink in Art Room 1204	0.8	ppb
26500-1204-S3	Sink in Art Room 1204	<0.1 *	ppb
26500-1208-S1	Food Service Sink-Hand Sink	1.5	ppb
26500-1208-S2	Food Service Sink-Food Prep	0.3	ppb
26500-1208-S4	Food Service Sink-Wash/Rinse	0.6	ppb
26500-1208-S5	Food Service Sink-Rinse/Sanitize	0.6	ppb
26500-1208-S6	Food Service Sink-Sprayer	1.8	ppb
26500-1208-S7	Food Service Sink-Hand Sink	1.6	ppb
26500-1207-DFL	Drinking Fountain in Cafeteria/Left	0.6	ppb
26500-1207-DFR	Drinking Fountain in Cafeteria/Right	0.3	ppb
26500-1006H-DFL	Hallway Drinking Fountain between Art Room and Cafeteria/Left	<0.1 *	ppb
26500-1006H-DFR	Hallway Drinking Fountain between Art Room and Cafeteria/Right	<0.1 *	ppb
26500-1214-S	Sink in Stage Room	1.1	ppb

26500-1214-SWB	Sink with Bubbler in Stage Room	0.2	ppb
26500-1004H-DFL	Hallway Drinking Fountain outside of Gym/Left	<0.1 *	ppb
26500-1004H-DFR	Hallway Drinking Fountain outside of Gym/Right	<0.1 *	ppb
26500-1108-S	Sink in Teacher's Lounge 1108	<0.1 *	ppb
26500-1110-S	Sink in Work Room 1110	2.9	ppb
26500-1104-S	Sink in Clinic	<0.1 *	ppb
26500-2401-S	Sink in Classroom 2401	0.6	ppb
26500-2402-S	Sink in Classroom 2402	0.1	ppb
26500-2403-S	Sink in Classroom 2403	<0.1 *	ppb
26500-2501-S	Sink in Classroom 2501	<0.1 *	ppb
26500-2502-S	Sink in Classroom 2502	0.5	ppb
26500-2503-S	Sink in Classroom 2503	1.8	ppb
26500-2504-S	Sink in Classroom 2504	1.9	ppb
26500-2505-S	Sink in Classroom 2505	0.2	ppb
26500-2506-S	Sink in Classroom 2506	0.7	ppb
26500-2016H-DFL	Hallway Drinking Fountain across from Classrooms 2502 and 2503/Left	<0.1 *	ppb
26500-2016H-DFR	Hallway Drinking Fountain across from Classrooms 2502 and 2503/Right	<0.1 *	ppb
26500-2513-S	Sink in Classroom 2513	<0.1 *	ppb
26500-2514-S	Sink in Classroom 2514	0.2	ppb
26500-2405-S	Sink in Classroom 2405	1.5	ppb
26500-2012H-DFL	Hallway Drinking Fountain across from Classrooms 2403 and 2402/Left	<0.1 *	ppb
26500-2012H-DFR	Hallway Drinking Fountain across from Classrooms 2403 and 2402/Right	<0.1 *	ppb
26500-2412-S	Sink in Classroom 2412	0.4	ppb
26500-2413-S	Sink in Classroom 2413	<0.1 *	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			