

Miller Special School - Sampled 6/10/16			
CustomerSampleNumber	Description	Lead Result	Units
54000-C102-S1	Sink in Classroom C102	4.0	ppb
54000-C102-S2	Sink in Classroom C102	3.9	ppb
54000-C102-S3	Sink in Classroom C102	3.2	ppb
54000-C103-S	Sink in Classroom C103	1.3	ppb
54000-C106-S	Sink in Classroom C106	0.5	ppb
54000-C108-S	Sink in Classroom C108	1.4	ppb
54000-C110-S	Sink in Classroom C110	0.8	ppb
54000-C111-S	Sink in Classroom C111	0.9	ppb
54000-C113-S	Sink in Classroom C113	2.2	ppb
54000-C114-S	Sink in Classroom C114	2.1	ppb
54000-C116-S	Sink in Classroom C116	2.7	ppb
54000-A112-SWB	Sink with Bubbler in Classroom A112	1.3	ppb
54000-A111-SWB	Sink with Bubbler in Classroom A111	1.9	ppb
54000-A110-SWB	Sink with Bubbler in Classroom A110	1.8	ppb
54000-A109-SWB	Sink with Bubbler in Classroom A109	1.3	ppb
54000-A102-SWB	Sink with Bubbler in Classroom A102	2.1	ppb
54000-A103-SWB	Sink with Bubbler in Classroom A103	2.2	ppb
54000-A104-SWB	Sink with Bubbler in Classroom A104	4.2	ppb
54000-A105-SWB	Sink with Bubbler in Classroom A105	1.1	ppb
54000-A106H-DF	Drinking Fountain in Hallway between A-Wing and B-Wing	0.8	ppb
54000-B105-SWB	Sink with Bubbler in Classroom B105	1.7	ppb
54000-B104-SWB	Sink with Bubbler in Classroom B104	2.5	ppb
54000-B103-SWB	Sink with Bubbler in Classroom B103	2.1	ppb
54000-B102-SWB	Sink with Bubbler in Classroom B102	1.3	ppb
54000-B107-SWB	Sink with Bubbler in Classroom B107	1.6	ppb
54000-B108-SWB	Sink with Bubbler in Classroom B108	3.5	ppb
54000-B109-SWB	Sink with Bubbler in Classroom B109	2.3	ppb
54000-B110-SWB	Sink with Bubbler in Classroom B110	2.5	ppb
54000-E127H-DF	Drinking Fountain in Hallway near Courtyard	0.6	ppb
54000-D105-SWB	Sink with Bubbler in Classroom D105	5.4	ppb
54000-D106-SWB	Sink with Bubbler in Classroom D106	1.5	ppb
54000-D109-SWB	Sink with Bubbler in Classroom D109	1.1	ppb
54000-D112-SWB	Sink with Bubbler in Classroom D112	1.5	ppb
54000-D114-S	Sink in Clinic	0.6	ppb
54000-D119-S1	Art Room Sink	1.3	ppb
54000-D119-S2	Art Room Sink	0.8	ppb
54000-E138H-DF	Drinking Fountain in Hallway near Multipurpose Room	1.6	ppb
54000-E148-S1	Food Service Sink	8.5	ppb
54000-E148-S2	Food Service Sink	3.5	ppb
54000-E148-S3	Food Service Sink	2.3	ppb
54000-REC-136-DF	Drinking Fountain in Temp REC-136	0.4	ppb
54000-REC-066-DF	Drinking Fountain in Temp REC-066	0.5	ppb
54000-REC-112-DF	Drinking Fountain in Temp REC-112	1.3	ppb
54000-REC-111-DF	Drinking Fountain in Temp REC-111	0.7	ppb
54000-RE-049-S	Sink in Temp RE-049	3.2	ppb