

Mount Carbon Elementary School - Sampled 10/20/16				Resampled** 1/19/17	
CustomerSampleNumber	Description	Lead Result	Unit	Lead Result	Unit
29400-112-S	Sink in Room 112	3.3	ppb		
29400-106-S	Sink in Clinic	2.8	ppb		
29400-217A-S	Sink in Music Room	9.1	ppb		
29400-217A-SWB	Sink with Bubbler in Music Room	0.2	ppb		
29400-202-S1	Food Service Sink-Hand Sink	6.2	ppb		
29400-202-S2	Food Service Sink-Sanitize/Rinse	1.7	ppb		
29400-202-S3	Food Service Sink-Rinse/Wash	1.2	ppb		
29400-202-S4	Food Service Sink-Sprayer	78.6	ppb	5.1	ppb
29400-202-S5	Food Service Sink-Hand Sink	6.3	ppb		
29400-202-S6	Food Service Sink-Hand Sink	5.0	ppb		
29400-202-S7	Food Service Sink-Sprayer	12.8	ppb		
29400-202-S8	Food Service Sink-Food Prep	1.8	ppb		
29400-202-S9	Food Service Sink-Food Prep Sprayer	5.3	ppb		
29400-200-S	Sink in Teacher's Lounge	<0.1 *	ppb		
29400-199H-DFL	Hallway Drinking Fountain across from Office 212/Left	<0.1 *	ppb		
29400-199H-DFR	Hallway Drinking Fountain across from Office 212/Right	<0.1 *	ppb		
29400-B-1-S	Sink in Classroom B-1	3.0	ppb		
29400-B-1-SWB	Sink with Bubbler in Classroom B-1	<0.1 *	ppb		
29400-B-2-S	Sink in Classroom B-2	2.9	ppb		
29400-B-2-SWB	Sink with Bubbler in Classroom B-2	0.1	ppb		
29400-B-3-S	Sink in Classroom B-3	2.7	ppb		
29400-B-3-SWB	Sink with Bubbler in Classroom B-3	<0.1 *	ppb		
29400-B-4-S	Sink in Classroom B-4	8.4	ppb		
29400-B-4-SWB	Sink with Bubbler in Classroom B-4	<0.1 *	ppb		
29400-B-5-S	Sink in Classroom B-5	3.7	ppb		
29400-B-5-SWB	Sink with Bubbler in Classroom B-5	<0.1 *	ppb		
29400-B-6-S	Sink in Classroom B-6	3.2	ppb		
29400-B-6-SWB	Sink with Bubbler in Classroom B-6	<0.1 *	ppb		
29400-G-1-S	Sink in Classroom G-1	6.0	ppb		
29400-G-1-SWB	Sink with Bubbler in Classroom G-1	<0.1 *	ppb		
29400-G-2-S	Sink in Classroom G-2	2.2	ppb		
29400-G-2-SWB	Sink with Bubbler in Classroom G-2	<0.1 *	ppb		
29400-G-3-S	Sink in Classroom G-3	4.5	ppb		
29400-G-3-SWB	Sink with Bubbler in Classroom G-3	<0.1 *	ppb		
29400-G-4-S	Sink in Classroom G-4	5.2	ppb		
29400-G-4-SWB	Sink with Bubbler in Classroom G-4	<0.1 *	ppb		
29400-G-5-S	Sink in Classroom G-5	8.7	ppb		
29400-G-5-SWB	Sink with Bubbler in Classroom G-5	<0.1 *	ppb		
29400-G-6-S	Sink in Classroom G-6	12.4	ppb		
29400-G-6-SWB	Sink with Bubbler in Classroom G-6	<0.1 *	ppb		
29400-145-S1	Art Room Sink	2.7	ppb		
29400-145-S2	Art Room Sink	3.6	ppb		
29400-145-S3	Art Room Sink	3.1	ppb		
29400-T-1-S	Sink in Classroom T-1	2.9	ppb		
29400-T-1-SWB	Sink with Bubbler in Classroom T-1	<0.1 *	ppb		
29400-T-2-S	Sink in Classroom T-2	4.5	ppb		
29400-T-2-SWB	Sink with Bubbler in Classroom T-2	<0.1 *	ppb		
29400-T-3-S	Sink in Classroom T-3	12.1	ppb		
29400-T-3-SWB	Sink with Bubbler in Classroom T-3	0.1	ppb		
29400-T-4-S	Sink in Classroom T-4	2.3	ppb		
29400-T-4-SWB	Sink with Bubbler in Classroom T-4	<0.1 *	ppb		
29400-T-5-S	Sink in Classroom T-5	1.9	ppb		
29400-T-5-SWB	Sink with Bubbler in Classroom T-5	<0.1 *	ppb		

29400-T-6-S	Sink in Classroom T-6	7.7	ppb	
29400-T-6-SWB	Sink with Bubbler in Classroom T-6	<0.1 *	ppb	
29400-M-1-S	Sink in Classroom M-1	15.2	ppb	0.9 ppb
29400-M-1-SWB	Sink with Bubbler in Classroom M-1	<0.1 *	ppb	
29400-M-2-S	Sink in Classroom M-2	5.7	ppb	
29400-M-2-SWB	Sink with Bubbler in Classroom M-2	<0.1 *	ppb	
29400-M-3-S	Sink in Classroom M-3	4.0	ppb	
29400-M-3-SWB	Sink with Bubbler in Classroom M-3	0.2	ppb	
29400-M-4-S	Sink in Kindergarten Classroom M-4	4.1	ppb	
29400-M-4-SWB	Sink with Bubbler in Kindergarten Classroom M-4	0.2	ppb	
29400-M-5-S	Sink in Kindergarten Classroom M-5	2.9	ppb	
29400-M-5-SWB	Sink with Bubbler in Kindergarten Classroom M-5	<0.1 *	ppb	
29400-M-6-S	Sink in Kindergarten Classroom M-6	4.3	ppb	
29400-M-6-SWB	Sink with Bubbler in Kindergarten Classroom M-6	<0.1 *	ppb	
29400-103-S	Sink in Conference Room 103	23.2	ppb	8.2 ppb
29400-154-S	Sink in Library Work Room	3.6	ppb	
29400-154-SWB	Sink with Bubbler in Library Work Room	0.1	ppb	
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.				
** Resampling results after elevated fixtures were repaired, or removed and replaced.				