

Oberon Middle School - Sampled 8/4/16			
CustomerSampleNumber	Description	Lead Result	Units
67700-207-S	Sink in Library Work Room	12.5	ppb
67700-S-1H-DFL	Hallway Drinking Fountain across from Laboratory S-1/Left	3.6	ppb
67700-S-1H-DFR	Hallway Drinking Fountain across from Laboratory S-1/Right	6.5	ppb
67700-S-1-S1	Sink in Laboratory S-1	9.6	ppb
67700-S-1-S2	Sink in Laboratory S-1	7.3	ppb
67700-138-S	Sink in Storage Room 138	16.7	ppb
67700-S-2-S1	Sink in Laboratory S-2	9.9	ppb
67700-S-2-S2	Sink in Laboratory S-2	6.7	ppb
67700-S-3-S1	Sink in Laboratory S-3	8.3	ppb
67700-S-3-S2	Sink in Laboratory S-3	11.6	ppb
67700-110H-DFL	Hallway Drinking Fountain across from Laboratory S-3/Left	0.7	ppb
67700-110H-DFR	Hallway Drinking Fountain across from Laboratory S-3/Right	2.0	ppb
67700-S-4-S1	Sink in Laboratory S-4	13.4	ppb
67700-S-4-S2	Sink in Laboratory S-4	8.8	ppb
67700-A-3-S1	Sink in Art Room A-3	133.8	ppb
67700-A-3-S2	Sink in Art Room A-3	68.2	ppb
67700-A-3-S3	Sink in Art Room A-3	39.2	ppb
67700-A-3-S4	Sink in Art Room A-3	41.9	ppb
67700-A-3-S5	Sink in Art Room A-3	27.1	ppb
67700-A-3-S6	Sink in Art Room A-3	95.9	ppb
67700-A-3-S7	Sink in Art Room A-3	36.3	ppb
67700-A-3-S8	Sink in Art Room A-3	29.0	ppb
67700-A-2-S1	Sink in Art Room A-2	88.0	ppb
67700-A-2-S2	Sink in Art Room A-2	36.9	ppb
67700-A-2-S3	Sink in Art Room A-2	19.3	ppb
67700-A-2-S4	Sink in Art Room A-2	14.2	ppb
67700-A-2-S5	Sink in Art Room A-2	31.7	ppb
67700-A-2-S6	Sink in Art Room A-2	26.0	ppb
67700-A-2-S7	Sink in Art Room A-2	27.6	ppb
67700-A-2-S8	Sink in Art Room A-2	35.8	ppb
67700-S-5-S1	Sink in Laboratory S-5	18.2	ppb
67700-S-5-S2	Sink in Laboratory S-5	26.2	ppb
67700-201H-DFL	Hallway Drinking Fountain across from Laboratory S-6/Left	3.3	ppb
67700-201H-DFR	Hallway Drinking Fountain across from Laboratory S-6/Right	1.3	ppb
67700-S-6-S1	Sink in Laboratory S-6	9.7	ppb
67700-S-6-S2	Sink in Laboratory S-6	19.9	ppb
67700-C-4-S	Sink in Consumer Science Classroom C-4	2.2	ppb
67700-C-5-S	Sink in Computer Room C-5	14.4	ppb
67700-C-6-S1	Sink in Classroom C-6	2.0	ppb
67700-C-6-S2	Sink in Classroom C-6	18.4	ppb
67700-301H-DFL	Hallway Drinking Fountain outside of Band Room/Left	4.8	ppb
67700-301H-DFR	Hallway Drinking Fountain outside of Band Room/Right	5.3	ppb
67700-BAND-S	Sink in Band Room	68.5	ppb
67700-BAND-SWB	Sink with Bubbler in Band Room	82.8	ppb
67700-TA1-S1	Sink in Exploration Room TA1	1.3	ppb
67700-TA1-S2	Sink in Exploration Room TA1	3.5	ppb

67700-TA1-SWB	Sink with Bubbler in Exploration Room TA1	0.7	ppb
67700-131-S1	Food Service Sink-Sprayer	6.8	ppb
67700-131-S2	Food Service Sink-Wash	6.6	ppb
67700-131-S3	Food Service Sink-Wash	13.5	ppb
67700-131-S4	Food Service Sink-Hand Sink	5.2	ppb
67700-131-S5	Food Service Sink-Food Prep	7.8	ppb
67700-107-DFL	Drinking Fountain in Cafeteria/Left	0.4	ppb
67700-107-DFR	Drinking Fountain in Cafeteria/Right	2.7	ppb
67700-115-S	Sink in Teacher's Lounge	5.5	ppb
67700-C-1-S2	Sink in Computer Room C-1	4.9	ppb
67700-105-S	Sink in Clinic	1.0	ppb
67700-106-S	Sink in Principal's Office	7.0	ppb
67700-112-DFL	Drinking Fountain in Cafeteria/Left	2.9	ppb
67700-112-DFR	Drinking Fountain in Cafeteria/Right	2.5	ppb