

Ralston Elementary School - Sampled 6/16/16			
CustomerSampleNumber	Description	Lead Result	Units
35000-208-S	Sink in Clinic	0.8	ppb
35000-208A-S	Sink in Clinic Restroom	2.7	ppb
35000-203H-DFL	Hallway Drinking Fountain near Office/Left	0.7	ppb
35000-203H-DFR	Hallway Drinking Fountain near Office/Right	0.7	ppb
35000-214-SWB	Sink with Bubbler in Classroom 214	39.4	ppb
35000-216-SWB	Sink with Bubbler in Classroom 216	22.3	ppb
35000-220-S	Sink in Bookroom	55.2	ppb
35000-220B-S	Sink in Restroom near Bookroom	10.2	ppb
35000-222-S	Sink in Teacher's Lounge	5.0	ppb
35000-222A-S	Sink in Teacher's Lounge Restroom	5.6	ppb
35000-224A-S	Sink in Office Restroom	13.3	ppb
35000-228-SWB	Sink with Bubbler in Office	187.3	ppb
35000-306-S	Sink in Teacher's Lounge	0.5	ppb
35000-306A-S	Sink in Teacher's Lounge Restroom	0.2	ppb
35000-310-S1	Sink in Community Room	9.3	ppb
35000-310-S2	Sink in Community Room	22.2	ppb
35000-314H-DFL	Hallway Drinking Fountain near Custodial Closet/Left	14.1	ppb
35000-314H-DFR	Hallway Drinking Fountain near Custodial Closet/Right	29.9	ppb
35000-318-SWB	Sink with Bubbler in Classroom 318	6.9	ppb
35000-229-S1	Art Room Sink	20.2	ppb
35000-229-S2	Art Room Sink	12.2	ppb
35000-229-S3	Art Room Sink	11.6	ppb
35000-229-S4	Art Room Sink	189.0	ppb
35000-225H-DF	Drinking Fountain in Hallway near Custodial Closet	1.5	ppb
35000-225H-WBFS	Hallway Water Bottle Filling Station	2.2	ppb
35000-102B-DFL	Drinking Fountain in Hallway near Custodial Closet/Left	0.8	ppb
35000-102B-DFR	Drinking Fountain in Hallway near Custodial Closet/Right	1.4	ppb
35000-104-SWB	Sink with Bubbler in Kindergarten Classroom 104	0.4	ppb
35000-106-SWB	Sink with Bubbler in Kindergarten Classroom 106	0.4	ppb
35000-108-SWB	Sink with Bubbler in Kindergarten Classroom 108	0.2	ppb
35000-107-SWB	Sink with Bubbler in Classroom 107	0.7	ppb
35000-109-SWB	Sink with Bubbler in Classroom 109	0.5	ppb
35000-111-SWB	Sink with Bubbler in Music Room	0.2	ppb
35000-302-S1	Food Service Sink	2.7	ppb
35000-302-S2	Food Service Sink	3.4	ppb
35000-302-S3	Food Service Sink	2.5	ppb
35000-302B-S	Sink in Kitchen Locker Room	0.6	ppb
3500-218-SWB	Sink with Bubbler in Classroom 218	33.4	ppb