

Rose Stein International Elementary School - Sampled 11/4/16			
CustomerSampleNumber	Description	Lead Result	Unit
43100-147-S	Sink in Clinic	3.3	ppb
43100-100.4H-DF	Hallway Drinking Fountain outside of Classroom 106	1.4	ppb
43100-102-S	Sink in Classroom 102	1.3	ppb
43100-100.1H-WBFS	Hallway Water Bottle Filling Station across from Gym	1.0	ppb
43100-100.1H-DF	Hallway Drinking Fountain across from Gym	1.7	ppb
43100-113-WBFS	Water Bottle Filling Station in the Gym	1.5	ppb
43100-113-DF	Drinking Fountain in Gym	2.1	ppb
43100-115-S	Sink in Stage Area	1.0	ppb
43100-116-S	Sink in Library Work Room	2.4	ppb
43100-120-S	Sink in Classroom 120	0.7	ppb
43100-122-S	Sink in Classroom 122	2.3	ppb
43100-124-S	Sink in Classroom 124	3.6	ppb
43100-126-S	Sink in Classroom 126	1.3	ppb
43100-125-S	Sink in Classroom 125	1.8	ppb
43100-123-S	Sink in Classroom 123	1.6	ppb
43100-100.5H-WBFS	Hallway Water Bottle Filling Station across from Classroom 130	2.3	ppb
43100-100.5H-DF	Hallway Drinking Fountain across from Classroom 130	2.0	ppb
43100-128-S	Sink in Art Room	9.3	ppb
43100-134H-DF	Hallway Drinking Fountain across from Classroom 135	1.4	ppb
43100-012-S1	Food Service Sink-Faucet over Soup Pot	2.9	ppb
43100-012-S2	Food Service Sink-Hand Sink	2.1	ppb
43100-012-S3	Food Service Sink-Sanitize/Rinse	9.9	ppb
43100-012-S4	Food Service Sink-Rinse/Wash	10.6	ppb
43100-012-S5	Food Service Sink-Food Prep	4.3	ppb
43100-012-S6	Food Service Sink-Hand Sink	0.7	ppb
43100-014-S1	Food Service Sink-Sprayer	2.5	ppb
43100-014-S2	Food Service Sink-Hand Sink	9.2	ppb
43100-R1-114-DF	Drinking Fountain in Temporary Classroom R1-114 (TEMP 1)	4.0	ppb
43100-R1-191-DF	Drinking Fountain in Temporary Classroom R1-191 (TEMP 2)	14.3	ppb