

Secrest Elementary School - Sampled 7/6/16			
CustomerSampleNumber	Description	Lead Result	Units
40000-A110-S	Sink in Assistant Principal's Office	3.7	ppb
40000-26-S	Sink in Classroom 26	3.3	ppb
40000-26-SWB	Sink with Bubblers in Classroom 26	0.4	ppb
40000-28-S	Sink in Classroom 28	29.8	ppb
40000-28-SWB	Sink with Bubblers in Classroom 28	0.6	ppb
40000-30-S	Sink in Classroom 30	0.8	ppb
40000-30-SWB	Sink with Bubblers in Classroom 30	0.4	ppb
40000-31-S	Sink in Classroom 31	0.6	ppb
40000-31-SWB	Sink with Bubblers in Classroom 31	0.6	ppb
40000-29-S	Sink in Classroom 29	4.5	ppb
40000-29-SWB	Sink with Bubblers in Classroom 29	0.3	ppb
40000-D01H-DF	Hallway Drinking Fountain near Classroom 24	20.5	ppb
40000-23-S	Sink in Classroom 23	0.8	ppb
40000-23-SWB	Sink with Bubblers in Classroom 23	1.3	ppb
40000-21-S	Sink in Classroom 21	1.5	ppb
40000-21-SWB	Sink with Bubblers in Classroom 21	8.1	ppb
40000-A17H-DF	Hallway Drinking Fountain near Office	0.8	ppb
40000-A44-S	Sink in Teacher's Lounge	1.4	ppb
40000-A39H-DF	Hallway Drinking Fountain near Music Room	1.0	ppb
40000-15-SWB	Sink with Bubblers in Classroom 15	5.7	ppb
40000-15-S	Sink in Classroom 15	2.7	ppb
40000-13-SWB	Sink with Bubblers in Classroom 13	2.5	ppb
40000-13-S	Sink in Classroom 13	3.8	ppb
40000-11-S1	Art Room Sink	10.6	ppb
40000-11-S2	Art Room Sink	2.9	ppb
40000-11-S3	Art Room Sink	1.4	ppb
40000-11-S4	Art Room Sink	1.1	ppb
40000-9-S	Sink in room between Art Room & Computer Lab	4.9	ppb
40000-7-S	Sink in Classroom 7	0.4	ppb
40000-7-SWB	Sink with Bubblers in Classroom 7	0.6	ppb
40000-6-S	Sink in Classroom 6	0.4	ppb
40000-6-SWB	Sink with Bubblers in Classroom 6	0.9	ppb
40000-5-S	Sink in Classroom 5	1.0	ppb
40000-5-SWB	Sink with Bubblers in Classroom 5	1.3	ppb
40000-3-S	Sink in Classroom 3	0.6	ppb
40000-3-SWB	Sink with Bubblers in Classroom 3	0.9	ppb
40000-1-S	Sink in Classroom 1	0.5	ppb
40000-1-SWB	Sink with Bubblers in Classroom 1	5.6	ppb
40000-2-S	Sink in Classroom 2	0.3	ppb
40000-2-SWB	Sink with Bubblers in Classroom 2	0.9	ppb
40000-4-S	Sink in Classroom 4	1.3	ppb
40000-4-SWB	Sink with Bubblers in Classroom 4	0.9	ppb

40000-C10H-DFL	Hallway Drinking Fountain near Classroom 5/Left	0.6	ppb
40000-C10H-DFR	Hallway Drinking Fountain near Classroom 5/Right	0.5	ppb
40000-10-S	Sink in Kindergarten Classroom 10	6.0	ppb
40000-10-SWB	Sink with Bubbler in Kindergarten Classroom 10	2.5	ppb
40000-12-S	Sink in Kindergarten Classroom 12	1.5	ppb
40000-12-SWB	Sink with Bubbler in Kindergarten Classroom 12	1.7	ppb
40000-14-DF	Drinking Fountain in Cafeteria	0.1	ppb
40000-B03-S1	Food Service Sink-Hand Wash	9.3	ppb
40000-B03-S2	Food Service Sink-Wash/Rinse/Sanitize	1.8	ppb
40000-A25-S	Sink in Clinic	1.0	ppb
40000-A24-S	Sink in Office Workroom	6.3	ppb