

Sierra Elementary School - Sampled 7/12/16			
CustomerSampleNumber	Description	Lead Result	Units
40500-38H-DF	Drinking Fountain in Hallway near old Gym (across from room 13)	4.3	ppb
40500-38H-S	Sink in Hallway near Library (across from room 15)	9.0	ppb
40500-38H-SWB	Sink with Bubbler in Hallway near Library (across from room 15)	3.1	ppb
40500-27-S	Sink in Planning Room 27	3.1	ppb
40500-88-S	Sink in ESL Office (Room 88)	26.2	ppb
40500-29H-S	Sink in Hallway near Library (across from room 8)	10.0	ppb
40500-29H-SWB	Sink with Bubbler in Hallway near Library (across from room 8)	3.6	ppb
40500-29H-DF	Drinking Fountain in Hallway near old Gym (across from room 11)	8.1	ppb
40500-09-S	Sink in Classroom 09	10.2	ppb
40500-09-SWB	Sink with Bubbler in Classroom 09	4.8	ppb
40500-06-S	Sink in Kindergarten Classroom 06	9.1	ppb
40500-06-SWB	Sink with Bubbler in Kindergarten Classroom 06	0.9	ppb
40500-05-S	Sink in Kindergarten Classroom 05	7.5	ppb
40500-05-SWB	Sink with Bubbler in Kindergarten Classroom 05	2.9	ppb
40500-04-S	Sink in Classroom 04	1.8	ppb
40500-04-SWB	Sink with Bubbler in Classroom 04	0.6	ppb
40500-50H-S	Sink in Hallway near Classroom 03	3.0	ppb
40500-50H-SWB	Sink with Bubbler in Hallway near Classroom 03	1.2	ppb
40500-46-S	Sink in Teacher's Lounge	4.5	ppb
40500-48H-S	Sink in Hallway near Classroom 21	2.6	ppb
40500-48H-SWB	Sink with Bubbler in Hallway near Classroom 21	1.0	ppb
40500-43-S	Sink in Server Room in Library (Room 43)	250.2	ppb
40500-44-S	Sink in Library Office (Room 44)	20.3	ppb
40500-20-S	Sink in Classroom 20	5.3	ppb
40500-20-SWB	Sink with Bubbler in Classroom 20	2.1	ppb
40500-19-S1	Sink in Art Room/Left	1.1	ppb
40500-19-S2	Sink in Art Room/Right	0.9	ppb
40500-16-S	Sink in Classroom 16	8.3	ppb
40500-16-SWB	Sink with Bubbler in Classroom 16	7.3	ppb
40500-15-S	Sink in Classroom 15	28.0	ppb
40500-15-SWB	Sink with Bubbler in Classroom 15	7.8	ppb
40500-RE-007-DF	Drinking Fountain in Temporary Classroom RE-007	14.3	ppb
40500-RE-054-DF	Drinking Fountain in Temporary Classroom RE-054	1.4	ppb
40500-113-S	Sink in Clinic	2.0	ppb
40500-106-S	Sink in Teacher's Lounge	1.8	ppb
40500-142-DFL	Drinking Fountain on Left at Entrance to Gym	2.3	ppb
40500-142-DFR	Drinking Fountain on Right at Entrance to Gym	1.9	ppb
40500-134-S1	Food Service Sink - Hand Sink	1.4	ppb
40500-134-S2	Food Service Sink - Sprayer	15.0	ppb
40500-134-S3	Food Service Sink - Wash/Rinse	3.7	ppb
40500-134-S4	Food Service Sink - Sanitize	3.6	ppb
40500-134-S5	Food Service Sink - Hand Sink	2.6	ppb
40500-134-S6	Food Service Sink - Sprayer	6.4	ppb
40500-134-S7	Food Service Sink - Food Prep	9.1	ppb
40500-134-S8	Food Service Sink - Food Prep Sprayer	10.5	ppb
40500-140-DFL	Drinking Fountain on Left in Cafeteria	2.0	ppb
40500-140-DFR	Drinking Fountain on Right in Cafeteria	3.9	ppb
40500-101H-DFL	Drinking Fountain in Hallway near Clinic	3.1	ppb
40500-101H-DFR	Drinking Fountain in Hallway near Clinic	1.5	ppb
40500-123-S	Sink in Workroom 123	1.3	ppb
40500-118-S	Sink in Classroom 118	1.2	ppb
40500-105-S	Sink in Conference Room 105	2.2	ppb