

Stevens Elementary School - Sampled 8/25/16			
CustomerSampleNumber	Description	Lead Result	Units
43300-1018-S	Sink in Classroom 1018	0.3	ppb
43300-1015-S	Sink in Classroom 1015	0.2	ppb
43300-1100H-DF	Hallway Drinking Fountain across from Classroom 1018	<0.1 *	ppb
43300-1014-S	Sink in Office 1014	0.3	ppb
43300-1007-S	Sink in Classroom 1007	<0.1 *	ppb
43300-1001-S1	Sink in Art Room 1001	7.2	ppb
43300-1001-S2	Sink in Art Room 1001	0.6	ppb
43300-1001-S3	Sink in Art Room 1001	2.7	ppb
43300-1031-S	Sink in Classroom 1031	0.6	ppb
43300-1033-S1	Sink in Classroom 1033	0.6	ppb
43300-1033-S2	Sink in Classroom 1033	1.6	ppb
43300-1033-S3	Sink in Classroom 1033	2.9	ppb
43300-1033-S4	Sink in Classroom 1033	1.6	ppb
43300-1057H-DF	Hallway Drinking Fountain across from Classroom 1033	<0.1 *	ppb
43300-1058-S	Sink in Classroom 1058	7.2	ppb
43300-1034-S	Sink in Science Prep Room 1034	12.9	ppb
43300-1036-S1	Sink in Classroom 1036	1.0	ppb
43300-1036-S2	Sink in Classroom 1036	1.1	ppb
43300-1036-S3	Sink in Classroom 1036	1.3	ppb
43300-1036-S4	Sink in Classroom 1036	0.5	ppb
43300-1046H-DF	Hallway Drinking Fountain across from Classroom 1039	<0.1 *	ppb
43300-1047-S	Sink in Community Room 1047	0.5	ppb
43300-1159-DF	Drinking Fountain in Boy's Locker Room	<0.1 *	ppb
43300-1142-DF	Drinking Fountain in Gym	0.2	ppb
43300-1147-DF	Drinking Fountain in Girl's Locker Room	0.1	ppb
43300-1116H-DF	Hallway Drinking Fountain outside of Cafeteria	<0.1 *	ppb
43300-1135-S1	Food Service Sink-Sprayer	3.0	ppb
43300-1135-S2	Food Service Sink-Food Prep	1.3	ppb
43300-1135-S3	Food Service Sink-Hose Connector Spigot	57.6	ppb
43300-1135-S4	Food Service Sink-Hand Sink	0.5	ppb
43300-1127-S1	Food Service Sink-Hand Sink	0.9	ppb
43300-1127-S2	Food Service Sink-Sprayer	1.9	ppb
43300-1127-S3	Food Service Sink-Wash/Rinse	2.1	ppb
43300-1127-S4	Food Service Sink-Wash/Sanitize	1.7	ppb
43300-1117-S	Sink in Band Room	10.8	ppb
43300-1117-SWB	Sink with Bubbler in Band Room	0.2	ppb
43300-1093-S	Sink in Classroom 1093	3.1	ppb
43300-1106-S	Sink in Clinic	2.8	ppb
43300-1111H-DF	Hallway Drinking Fountain near Main Office	<0.1 *	ppb
43300-1087-S	Sink in Teacher's Lounge	0.2	ppb
43300-2031-S	Sink in Classroom 2031	7.2	ppb
43300-2030H-DF	Hallway Drinking Fountain across from Classroom 2008	<0.1 *	ppb
43300-2009-S	Sink in Science Prep Room 2009	6.8	ppb
43300-2020H-DF	Hallway Drinking Fountain across from Classroom 2014	<0.1 *	ppb
43300-2021-S	Sink in Classroom 2021	17.3	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.