

Stony Creek Elementary - Sampled 6/8/16				Resampled** 11/10/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
43600-112-S	Sink in Office Planning Room	6.5	ppb		
43600-113-S	Sink in Clinic	5.9	ppb		
43600-120-S1	Art Room Sink	11.3	ppb		
43600-120-S2	Art Room Sink	13.8	ppb		
43600-120-S3	Art Room Sink	10.4	ppb		
43600-120-S4	Art Room Sink	8.5	ppb		
43600-106XH-DF	Hallway Drinking Fountain Near Cafeteria	0.5	ppb		
43600-106X-S1	Food Service Sink	7.4	ppb		
43600-106X-S2	Food Service Sink - Wash & Rinse	19.7	ppb	0.5	ppb
43600-106X-S3	Food Service Sink	4.4	ppb		
43600-311-DF	300 Pod Drinking Fountain	6.1	ppb		
43600-211-DF	200 Pod Drinking Fountain	6.6	ppb		
43600-137-S	Sink in 100 Pod Near Restrooms	3.7	ppb		
43600-137-DF	100 Pod Drinking Fountain	4.3	ppb		
43600-122-S	Sink in Library Workroom	12.2	ppb		
43600-126H-DF	Hallway Drinking Fountain	2.2	ppb		
43600-128-S	Sink in Teacher's Lounge	2.8	ppb		
43600-2-SWB	Sink with Bubbler in Kingergarten Room 2	3.8	ppb		
43600-1-SWB	Sink with Bubbler in Kingergarten Room 1	5.4	ppb		
43600-R1-122-DF	Drinking Fountain in Temp R1-122	10.7	ppb		
43600-R1-43-DF	Drinking Fountain in Temp R1-43	14.8	ppb		
43600-R1-223-DF	Drinking Fountain in Temp R1-223	29.6	ppb	Fixture Removed	
43600-RE-041-DF	Drinking Fountain in Temp RE-041	1.5	ppb		
43600-REC-102-DF	Drinking Fountain in Temp REC-102	0.6	ppb		
43600-REC-087-DF	Drinking Fountain in Temp REC-087	1.1	ppb		
43600-R1-019-DF	Drinking Fountain in Temp R1-019	10.7	ppb		
43600-RD-080-DF	Drinking Fountain in Temp R1-080	8.0	ppb		
43600-R1-099-DF	Drinking Fountain in Temp R1-099	1.9	ppb		
43600-R1-223-S	Sink in Temp R1-223	0.3	ppb		
43600-RE-041-S	Sink in Temp REC-041	0.7	ppb		
43600-REC-102-S	Sink in Temp REC-102	0.5	ppb		
43600-REC-087-S	Sink in Temp REC-087	0.4	ppb		
43600-R1-019-S	Sink in Temp R1-019	5.9	ppb		
43600-R1-099-S	Sink in Temp R1-099	7.0	ppb		

** Resampling results after elevated fixtures were removed and replaced.