

Summit Ridge Middle School - Sampled 9/22/16			
CustomerSampleNumber	Description	Lead Result	Units
67800-0206-S1	Sink in Laboratory 0206	7.9	ppb
67800-0206-S2	Sink in Laboratory 0206	8.4	ppb
67800-0206-S3	Sink in Laboratory 0206	11.7	ppb
67800-0206-S4	Sink in Laboratory 0206	6.0	ppb
67800-1012H-DF	Hallway Drinking Fountain across from Laboratory 0206	<0.1 *	ppb
67800-1019-S	Sink in Science Prep Room 1019	4.5	ppb
67800-0209-S1	Sink in Laboratory 0209	3.3	ppb
67800-0209-S2	Sink in Laboratory 0209	7.4	ppb
67800-0209-S3	Sink in Laboratory 0209	6.3	ppb
67800-0209-S4	Sink in Laboratory 0209	4.8	ppb
67800-1030-DF	Hallway Drinking Fountain across from Laboratory 0209	<0.1 *	ppb
67800-1143-DF	Drinking Fountain in Cafeteria	0.2	ppb
67800-1044-S	Sink in Teacher's Lounge	2.1	ppb
67800-1046-S1	Food Service Sink-Sprayer	2.6	ppb
67800-1046-S2	Food Service Sink-Wash	1.9	ppb
67800-1046-S3	Food Service Sink-Rinse	2.6	ppb
67800-1046-S4	Food Service Sink-Food Prep	6.9	ppb
67800-1046-S5	Food Service Sink-Food Prep	2.4	ppb
67800-1046-S6	Food Service Sink-Sprayer	116.1	ppb
67800-1046-S7	Food Service Sink-Hand Sink	0.9	ppb
67800-0109-S	Sink in Orchestra Room	11.5	ppb
67800-0109-SWB	Sink with Bubbler in Orchestra Room	0.3	ppb
67800-0110-DF	Drinking Fountain in Vocal Music Room	0.1	ppb
67800-0108-SWB	Sink with Bubbler in Exploration Room 0108	1.0	ppb
67800-0108-S	Sink in Exploration Room 0108	18.3	ppb
67800-0107-SWB	Sink with Bubbler in Exploration Room 0107	1.3	ppb
67800-0107-S	Sink in Exploration Room 0107	40.3	ppb
67800-0108A-S	Sink in Exploration Room 0108A	9.6	ppb
67800-1082-DF	Drinking Fountain across from Control Room 1068	<0.1 *	ppb
67800-0103-S1	Art Room Sink	3.0	ppb
67800-0103-S2	Art Room Sink	1.7	ppb
67800-0102-S	Sink in Consumer Science Room 0102	10.8	ppb
67800-0101-S1	Sink in Kitchen Classroom 0101	5.8	ppb
67800-0101-S2	Sink in Kitchen Classroom 0101	1.9	ppb
67800-0101-S3	Sink in Kitchen Classroom 0101	5.6	ppb
67800-0101-S4	Sink in Kitchen Classroom 0101	5.3	ppb
67800-0101-S5	Sink in Kitchen Classroom 0101	5.2	ppb
67800-0101-S6	Sink in Kitchen Classroom 0101	3.6	ppb
67800-0101-S7	Sink in Kitchen Classroom 0101	0.3	ppb
67800-1090H-DF	Hallway Drinking Fountain down from 1st Floor Elevator	<0.1 *	ppb
67800-1093-DF	Drinking Fountain in Gym	0.5	ppb
67800-1123-S	Sink in Counselor Office's Hallway	1.2	ppb
67800-1135-S	Sink in Clinic	1.9	ppb
67800-2069-S	Sink in Library Work Room	3.6	ppb
67800-0306-S1	Sink in Laboratory 0306	5.6	ppb
67800-0306-S2	Sink in Laboratory 0306	2.8	ppb

67800-0306-S3	Sink in Laboratory 0306	5.6	ppb
67800-0306-S4	Sink in Laboratory 0306	3.1	ppb
67800-2009H-DF	Hallway Drinking Fountain across from Laboratory 0306	<0.1 *	ppb
67800-2016-S	Sink in Science Prep Room 2016	3.2	ppb
67800-0309-S1	Sink in Laboratory 0309	6.5	ppb
67800-0309-S2	Sink in Laboratory 0309	10.3	ppb
67800-0309-S3	Sink in Laboratory 0309	11.7	ppb
67800-0309-S4	Sink in Laboratory 0309	3.3	ppb
67800-2026H-DF	Hallway Drinking Fountain across from Laboratory 0309	<0.1 *	ppb
67800-2039H-DF	Hallway Drinking Fountain across from Laboratory 0409	<0.1 *	ppb
67800-0409-S1	Sink in Laboratory 0409	4.2	ppb
67800-0409-S2	Sink in Laboratory 0409	2.3	ppb
67800-0409-S3	Sink in Laboratory 0409	4.5	ppb
67800-0409-S4	Sink in Laboratory 0409	8.1	ppb
67800-2046-S	Sink in Science Prep Room 2046	6.2	ppb
67800-0406-S1	Sink in Laboratory 0406	14.3	ppb
67800-0406-S2	Sink in Laboratory 0406	6.0	ppb
67800-0406-S3	Sink in Laboratory 0406	6.6	ppb
67800-0406-S4	Sink in Laboratory 0406	2.4	ppb
67800-2061H-DF	Hallway Drinking Fountain across from Laboratory 0406	<0.1 *	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			