

Thomson Elementary School - Sampled 7/14/16			
CustomerSampleNumber	Description	Lead Result	Units
43900-004H-DF	Hallway Drinking Fountain near Art Room	10.6	ppb
43900-001-S	Sink in Kindergarten Classroom 001	18.0	ppb
43900-001-SWB	Sink with Bubbler in Kindergarten Classroom 001	5.2	ppb
43900-002-S	Sink in Kindergarten Classroom 002	6.0	ppb
43900-002-SWB	Sink with Bubbler in Kindergarten Classroom 002	4.3	ppb
43900-81H-S	Hallway Sink across from Main Office	5.9	ppb
43900-81H-SWB	Hallway Sink with Bubbler across from the Main Office	4.9	ppb
43900-060-S	Sink in Clinic	1.3	ppb
43900-060-SWB	Sink with Bubbler in Clinic	2.7	ppb
43900-040-S	Sink in Office next to Principal's Office	10.0	ppb
43900-071H-S2	Hallway Sink across from Kitchen	2.0	ppb
43900-071H-SWB2	Hallway Sink with Bubbler across from Kitchen	2.7	ppb
43900-071H-S1	Hallway Sink across from Kitchen	1.9	ppb
43900-071H-SWB1	Hallway Sink with Bubbler across from Kitchen	1.8	ppb
43900-004-S1	Art Room Sink	0.9	ppb
43900-004-S2	Art Room Sink	1.1	ppb
43900-74-S	Sink in Library Work Room	5.7	ppb
43900-009-S	Sink in Classroom 009	9.8	ppb
43900-010H-S	Hallway Sink across from Classroom 010	5.9	ppb
43900-010H-SWB	Hallway Sink with Bubbler across from Classroom 010	5.4	ppb
43900-011-S	Sink in Classroom 011	1.7	ppb
43900-013-S	Sink in Classroom 013	1.0	ppb
43900-014H-S	Sink in Hallway across from Classroom 014	28.0	ppb
43900-014H-SWB	Hallway Sink with Bubbler across from Classroom 014	7.2	ppb
43900-015-S	Sink in Classroom 015	0.9	ppb
43900-017-S	Sink in Classroom 017	21.3	ppb
43900-031-S1	Food Service Sink-Food Prep	39.4	ppb
43900-031-S2	Food Service Sink-Food Prep	7.0	ppb
43900-031-S3	Food Service Sink-Wash/Rinse	9.7	ppb
43900-031-S4	Food Service Sink-Wash/Rinse	148.3	ppb
43900-031-S5	Food Service Sink- Sprayer	21.5	ppb
43900-031-S6	Food Service Sink- Hand Sink	19.9	ppb
43900-030-S	Sink in Cafeteria	0.5	ppb
43900-030-SWB	Sink with Bubbler in Cafeteria	0.5	ppb
43900-108-S	Sink in Teacher's Lounge	5.0	ppb
43900-021-S	Sink in Classroom 021	8.0	ppb
43900-021-SWB	Sink with Bubbler in Classroom 021	0.1	ppb
43900-023-S	Sink in Classroom 023	20.6	ppb
43900-023-SWB	Sink with Bubbler in Classroom 023	0.2	ppb
43900-120H-DF	Hallway Drinking Fountain across from Rooms 024 and 026	0.2	ppb
43900-025-S	Sink in Classroom 025	18.4	ppb
43900-025-SWB	Sink with Bubbler in Classroom 025	0.1	ppb
43900-027-S	Sink in Classroom 027	18.5	ppb
43900-027-SWB	Sink with Bubbler in Classroom 027	<0.1 *	ppb
43900-028-S	Sink in Classroom 028	29.4	ppb
43900-028-SWB	Sink with Bubbler in Classroom 028	0.2	ppb
43900-026-S	Sink in Classroom 026	1.3	ppb

43900-026-SWB	Sink with Bubbler in Classroom 026	0.1	ppb
43900-024-S	Sink in Classroom 024	23.5	ppb
43900-024-SWB	Sink with Bubbler in Classroom 024	1.5	ppb
43900-022-S	Sink in Classroom 022	4.1	ppb
43900-022-SWB	Sink with Bubbler in Classroom 022	0.2	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			