

Warder Elementary School - Sampled 7/6/16				Resampled** 8/9/16	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
44800-131-S	Sink in Classroom 131	7.3	ppb		
44800-131-SWB	Sink with Bubbler in Classroom 131	0.3	ppb		
44800-133-S	Sink in Classroom 133	27.4	ppb	1.7	ppb
44800-133-SWB	Sink with Bubbler in Classroom 133	0.1	ppb		
44800-135-S	Sink in Classroom 135	1.0	ppb		
44800-135-SWB	Sink with Bubbler in Classroom 135	0.2	ppb		
44800-137-S	Sink in Classroom 137	29.3	ppb	2.2	ppb
44800-137-SWB	Sink with Bubbler in Classroom 137	0.2	ppb		
44800-134-S	Sink in Classroom 134	4.4	ppb		
44800-134-SWB	Sink with Bubbler in Classroom 134	0.3	ppb		
44800-132-S	Sink in Classroom 132	6.5	ppb		
44800-132-SWB	Sink with Bubbler in Classroom 132	0.2	ppb		
44800-111H-S	Sink in Hallway across from Classroom 133	0.7	ppb		
44800-111H-SWB	Sink with Bubbler in Hallway across from Classroom 133	0.6	ppb		
44800-130-S	Sink in Classroom 130	27.4	ppb	1.5	ppb
44800-130-SWB	Sink with Bubbler in Classroom 130	0.2	ppb		
44800-128-S	Sink in Kindergarten Classroom 128	22.4	ppb	5.6	ppb
44800-128-SWB	Sink with Bubbler in Kindergarten Classroom 128	3.3	ppb		
44800-127-S	Sink in Kindergarten Classroom 127	3.6	ppb		
44800-127-SWB	Sink with Bubbler in Kindergarten Classroom 127	2.1	ppb		
44800-139H-S	Sink in Hallway outside of Library	2.9	ppb		
44800-139H-SWB	Sink with Bubbler in Hallway outside of Library	4.5	ppb		
44800-104-S	Sink in Clinic	25.2	ppb	5.3	ppb
44800-104-SWB	Sink with Bubbler in Clinic	11.6	ppb		
44800-141-S	Sink in Library Workroom	197.0	ppb	4.1	ppb
44800-122-S	Sink in Teacher's Lounge	0.9	ppb		
44800-47H-S1	Sink in Hallway outside of Kitchen	2.7	ppb		
44800-47H-SWB1	Sink with Bubbler in Hallway outside of Kitchen	5.1	ppb		
44800-47H-S2	Sink in Hallway outside of Kitchen	3.6	ppb		
44800-47H-SWB2	Sink with Bubbler in Hallway outside of Kitchen	3.7	ppb		
44800-117-S1	Food Service Sink-Food Prep	37.9	ppb	5.2	ppb
44800-117-S2	Food Service Sink-Food Prep	26.4	ppb		Fixture Removed
44800-117-S3	Food Service Sink-Rinse	9.4	ppb		
44800-117-S4	Food Service Sink-Wash	12.1	ppb		
44800-117-S5	Food Service Sink-Hand Wash	2.0	ppb		
44800-118-S	Sink in Classroom 118	16.8	ppb	0.8	ppb
44800-118-SWB	Sink with Bubbler in Classroom 118	0.4	ppb		
44800-112-S	Sink in Classroom 112	11.5	ppb		
44800-112-SWB	Sink with Bubbler in Classroom 112	0.7	ppb		
44800-114-S	Sink in Classroom 114	15.5	ppb	0.8	ppb
44800-126H-S	Sink in Hallway across from Classroom 112	4.5	ppb		
44800-126H-SWB	Sink with Bubbler in Hallway across from Classroom 112	2.2	ppb		
44800-113-S	Sink in Classroom 113	2.2	ppb		
44800-129H-S	Sink in Hallway across from Classroom 106	7.3	ppb		
44800-129H-SWB	Sink with Bubbler in Hallway across from Classroom 106	7.7	ppb		
44800-103-S1	Art Room Sink	13.4	ppb		
44800-103-S2	Art Room Sink	6.3	ppb		
44800-101H-DF	Hallway Drinking Fountain across from Counselor Office	12.6	ppb		

\*\* Resampling Results after elevated fixtures were removed and replaced.