

WarrenTech North Campus - Sampled 10/25/16			
CustomerSampleNumber	Description	Lead Result	Unit
55020-A110-S	Sink in Clinic	2.5	ppb
55020-A109-S	Sink in Planning Room A109	0.9	ppb
55020-A135H-DFL	Hallway Drinking Fountain outside of Library/Left	0.4	ppb
55020-A135H-DFR	Hallway Drinking Fountain outside of Library/Right	2.1	ppb
55020-A135H-WBFS	Water Bottle Filling Station outside of Library	0.7	ppb
55020-A146-S	Sink in Technology Lab A146	1.7	ppb
55020-A142-S	Sink in Lab Classroom A142	1.6	ppb
55020-A210-S	Sink in Nursing Lab A210	15.8	ppb
55020-A219-S	Sink in Sports Medicine Classroom A219	28.3	ppb
55020-A215H-DFL	Main Hallway Drinking Fountain on 2nd Floor/Left	1.3	ppb
55020-A215H-DFR	Main Hallway Drinking Fountain on 2nd Floor/Right	1.9	ppb