

West Woods Elementary School - Sampled 9/1/16				Resampled** 11/22/16	
CustomerSampleNumber	Description	Lead Result	Unit	Lead Result	Units
47700-160-S	Sink in Clinic	1.8	ppb		
47700-163-S	Sink in Teachers' Lounge	0.2	ppb		
47700-214-S	Sink in Classroom 214	19.5	ppb	1.4	ppb
47700-214-SWB	Sink with Bubbler in Classroom 214	0.1	ppb		
47700-207H-DF	Hallway Drinking Fountain across from Classroom 214	<0.1	ppb		
47700-213-S	Sink in Classroom 213	13.9	ppb		
47700-213-SWB	Sink with Bubbler in Classroom 213	0.1	ppb		
47700-212-S	Sink in Classroom 212	14.3	ppb		
47700-212-SWB	Sink with Bubbler in Classroom 212	0.1	ppb		
47700-201-S	Sink in Classroom 201	14.7	ppb		
47700-201-SWB	Sink with Bubbler in Classroom 201	<0.1	ppb		
47700-200-S	Sink in Classroom 200	12.4	ppb		
47700-200-SWB	Sink with Bubbler in Classroom 200	<0.1	ppb		
47700-199-S	Sink in Classroom 199	14.0	ppb		
47700-199-SWB	Sink with Bubbler in Classroom 199	<0.1	ppb		
47700-197-S	Sink in Classroom 197	17.7	ppb	1.2	ppb
47700-197-SWB	Sink with Bubbler in Classroom 197	<0.1	ppb		
47700-196-S	Sink in Classroom 196	13.5	ppb		
47700-196-SWB	Sink with Bubbler in Classroom 196	0.2	ppb		
47700-190H-DF	Hallway Drinking Fountain across from Classroom 196	<0.1	ppb		
47700-195-S	Sink in Classroom 195	11.4	ppb		
47700-195-SWB	Sink with Bubbler in Classroom 195	0.1	ppb		
47700-185-S	Sink in Classroom 185	0.2	ppb		
47700-185-SWB	Sink with Bubbler in Classroom 185	13.6	ppb		
47700-184-S	Sink in Classroom 184	5.1	ppb		
47700-184-SWB	Sink with Bubbler in Classroom 184	<0.1	ppb		
47700-183-S	Sink in Classroom 183	12.1	ppb		
47700-183-SWB	Sink with Bubbler in Classroom 183	<0.1	ppb		
47700-178-S1	Food Service Sink - Hand Sink	1.4	ppb		
47700-178-S2	Food Service Sink - Rinse/Sanitize	1.6	ppb		
47700-178-S3	Food Service Sink - Wash/Rinse	1.0	ppb		
47700-178-S4	Food Service Sink - Sprayer	3.3	ppb		
47700-178-S5	Food Service Sink - Food Prep Sink	6.8	ppb		
47700-178-S6	Food Service Sink - Food Prep Sink	1.9	ppb		
47700-174-S1	Food Service Sink - Hand Sink	5.8	ppb		
47700-174-S2	Food Service Sink - Spayer	0.3	ppb		
47700-146-S	Sink in Library Workroom	2.6	ppb		
47700-157H-DF	Hallway Drinking Fountain near Music Room	<0.1	ppb		
47700-135-S	Sink in Music Room	448.2	ppb	1.7	ppb
47700-135-SWB	Sink With Bubbler in Music Room	0.8	ppb		
47700-151-S1	Sink in Art Room 151	1.3	ppb		
47700-151-S2	Sink in Art Room 151	1.2	ppb		
47700-101-S	Sink in Classroom 101	14.5	ppb		
47700-101-SWB	Sink with Bubbler in Classroom 101	<0.1	ppb		
47700-102-S	Sink in Classroom 102	7.0	ppb		
47700-102-SWB	Sink with Bubbler in Classroom 102	<0.1	ppb		
47700-107H-DF	Hallway Drinking Fountain Across from Classroom 103	0.2	ppb		
47700-103-S	Sink in Classroom 103	28.1	ppb	0.9	ppb
47700-103-SWB	Sink with Bubbler in Classroom 103	<0.1	ppb		
47700-104-S	Sink in Classroom 104	5.8	ppb		
47700-104-SWB	Sink with Bubbler in Classroom 104	<0.1	ppb		
47700-113-S	Sink in Classroom 113	10.1	ppb		
47700-113-SWB	Sink with Bubbler in Classroom 113	<0.1	ppb		
47700-114-S	Sink in Classroom 114	17.9	ppb	0.6	ppb
47700-114-SWB	Sink with Bubbler in Classroom 114	<0.1	ppb		
47700-116-S	Sink in Classroom 116	9.4	ppb		
47700-116-SWB	Sink with Bubbler in Classroom 116	0.2	ppb		
47700-117-S	Sink in Classroom 117	8.7	ppb		
47700-117-SWB	Sink with Bubbler in Classroom 117	0.1	ppb		

47700-122H-DF	Hallway Drinking Fountain across from Clsroom 117	0.1	ppb	
47700-118-S	Sink in Classroom 118	13.0	ppb	
47700-118-SWB	Sink with Bubbler in Classroom 118	0.1	ppb	
47700-128-S	Sink in Classroom 128	7.8	ppb	
47700-128-SWB	Sink with Bubbler in Classroom 128	<0.1	ppb	
47700-129-S	Sink in Classroom 129	16.8	ppb	0.6 ppb
47700-129-SWB	Sink with Bubbler in Classroom 129	<0.1	ppb	
47700-130-S	Sink in Classroom 130	20.0	ppb	0.6 ppb
47700-130-SWB	Sink with Bubbler in Classroom 130	<0.1	ppb	
47700-R1-104-DF	Drinking Fountain in TEMP R1-104	4.0	ppb	
47700-R1-105-DF	Drinking Fountain in TEMP R1-105	8.8	ppb	
47700-R1-109-DF	Drinking Fountain in TEMP R1-109	9.0	ppb	
47700-R1-103-DF	Drinking Fountain in TEMP R1-103	5.7	ppb	
47700-R1-143-DF	Drinking Fountain in TEMP R1-143	20.0	ppb	9.8 ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.				
** Resampling results after elevated fixtures were removed and replaced.				