

Westgate Elementary School - Sampled 6/15/16			
CustomerSampleNumber	Description	Lead Result	Units
45600-180H-DF	Hallway Drinking Fountain near Classroom 180	0.1	ppb
45600-183H-DF	Hallway Drinking Fountain near Classroom 183	<0.1 *	ppb
45600-E101-SWB1	Sink with Bubblers in Kindergarten Classroom E101	1.0	ppb
45600-E101-SWB2	Sink with Bubblers in Kindergarten Classroom E101	0.4	ppb
45600-311X-SWB	Sink with Bubblers in Clinic	0.4	ppb
45600-195H-DF	Hallway Drinking Fountain near Cafeteria	0.2	ppb
45600-194H-DF	Hallway Drinking Fountain near Cafeteria	<0.1 *	ppb
45600-E125-DF	Hallway Drinking Fountain near Room E162	3.9	ppb
45600-E162-S	Sink in Classroom E162	1.5	ppb
45600-328XH-SWB	Hallway Sink with Bubblers	0.5	ppb
45600-327XH-SWB	Hallway Sink with Bubblers	0.4	ppb
45600-E113-S1	Food Service Sink-Hose Connection Spigot	101.4	ppb
45600-E113-S2	Food Service Sink-Food Prep	3.5	ppb
45600-E113-S3	Food Service Sink-Wash/Rinse	4.8	ppb
45600-E113-S4	Food Service Sink-Rinse/Sanitize	4.2	ppb
45600-E113-S5	Food Service Sink-Hand Sink	2.5	ppb
45600-300XH-SWB	Hallway Sink with Bubblers near Classroom E176	0.5	ppb
45600-307XH-SWB	Hallway Sink with Bubblers near Classroom E167	0.4	ppb
45600-325XH-SWB	Hallway Sink with Bubblers near Library	0.7	ppb
45600-E146-S4	Art Room Sink	4.3	ppb
45600-E146-S1	Art Room Sink	0.8	ppb
45600-E146-S2	Art Room Sink	0.8	ppb
45600-E146-S3	Art Room Sink	0.4	ppb
45600-145-DF	Hallway Drinking Fountain near Office	0.6	ppb
45600-309AX-S	Sink in Teacher's Lounge	0.4	ppb
45600-R1-202-DF	Drinking Fountain in Temp R1-202	2.3	ppb
45600-R1-203-DF	Drinking Fountain in Temp R1-203	2.1	ppb
45600-R1-205-DF	Drinking Fountain in Temp R1-205	0.4	ppb
45600-R1-205-S	Sink in Temp R1-205	0.5	ppb
45600-RE-026-DF	Drinking Fountain in Temp RE-026	0.4	ppb
45600-RE-026-S	Sink in Temp RE-026	1.5	ppb
45600-RE-025-DF	Drinking Fountain in Temp RE-025	1.0	ppb
45600-R1-015-DF	Drinking Fountain in Temp R1-015	8.8	ppb
45600-RE-024-DF	Drinking Fountain in Temp RE-024	1.3	ppb
45600-REC-105-S	Sink in Temp REC-105	0.4	ppb
45600-321X-S	Sink in Room 321X	1.5	ppb

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.