

West Jefferson Middle School - Sampled 10/4/16			
CustomerSampleNumber	Description	Lead Result	Units
68000-111-S1	Sink in Classroom 111	14.2	ppb
68000-111-S2	Sink in Classroom 111	13.0	ppb
68000-112-S1	Sink in Laboratory 112	5.6	ppb
68000-112-S2	Sink in Laboratory 112	7.3	ppb
68000-112-S3	Sink in Laboratory 112	0.9	ppb
68000-112-S4	Sink in Laboratory 112	1.8	ppb
68000-16-S	Sink in Science Prep Room 16	14.0	ppb
68000-110-S1	Sink in Laboratory 110	6.5	ppb
68000-110-S2	Sink in Laboratory 110	10.0	ppb
68000-110-S3	Sink in Laboratory 110	8.7	ppb
68000-110-S4	Sink in Laboratory 110	9.6	ppb
68000-108-S1	Sink in Laboratory 108	13.5	ppb
68000-108-S2	Sink in Laboratory 108	8.0	ppb
68000-108-S3	Sink in Laboratory 108	5.6	ppb
68000-108-S4	Sink in Laboratory 108	8.2	ppb
68000-21-S	Sink in Science Prep Room 21	6.5	ppb
68000-106-S1	Sink in Laboratory 106	14.0	ppb
68000-C3H-DFL	Hallway Drinking Fountain across from Classrooms 305/Left	6.2	ppb
68000-C3H-DFR	Hallway Drinking Fountain across from Classrooms 305/Right	5.2	ppb
68000-307-S1	Sink in Laboratory 307	3.4	ppb
68000-307-S2	Sink in Laboratory 307	4.7	ppb
68000-307-S3	Sink in Laboratory 307	1.7	ppb
68000-307-S4	Sink in Laboratory 307	2.4	ppb
68000-105-S1	Sink in Science Prep Room 105	5.3	ppb
68000-105-S2	Sink in Science Prep Room 105	5.3	ppb
68000-308-S1	Sink in Laboratory 308	6.1	ppb
68000-308-S2	Sink in Laboratory 308	17.3	ppb
68000-308-S3	Sink in Laboratory 308	5.2	ppb
68000-308-S4	Sink in Laboratory 308	8.7	ppb
68000-C5H-DFL	Hallway Drinking Fountain across from Classroom 306/Left	3.5	ppb
68000-C5H-DFR	Hallway Drinking Fountain across from Classroom 306/Right	3.7	ppb
68000-120-S	Sink in Planning Room 120	18.5	ppb
68000-116-S	Sink in Planning Room 116	7.1	ppb
68000-C6H-DFL	Hallway Drinking Fountain on 1st Floor near Elevator/Left	3.1	ppb
68000-C6H-DFR	Hallway Drinking Fountain on 1st Floor near Elevator/Right	3.6	ppb
68000-C8H-DFL	Hallway Drinking Fountain near Library/Left	3.6	ppb
68000-C8H-DFR	Hallway Drinking Fountain near Library/Right	3.4	ppb
68000-402-S1	Sink in FACS Kitchen Classroom	2.7	ppb
68000-402-S2	Sink in FACS Kitchen Classroom	0.6	ppb
68000-402-S3	Sink in FACS Kitchen Classroom	0.8	ppb
68000-402-S4	Sink in FACS Kitchen Classroom	0.8	ppb
68000-402-S5	Sink in FACS Kitchen Classroom	0.4	ppb
68000-402-S6	Sink in FACS Kitchen Classroom	1.7	ppb
68000-48-S	Sink in Teachers' Lounge	1.1	ppb
68000-38-S	Sink in Library Workroom	2.5	ppb
68000-404-S1	Sink in Art Classroom 404/Left	1.6	ppb
68000-404-S2	Sink in Art Classroom 404/Right	0.6	ppb

68000-406-S1	Sink in Art Classroom 406/Left	1.4	ppb
68000-406-S2	Sink in Art Classroom 406/Right	1.5	ppb
68000-79H-DFL	Hallway Drinking Fountain near Restrooms near Band Room/Left	2.9	ppb
68000-79H-DFR	Hallway Drinking Fountain near Restrooms near Band Room/Right	1.3	ppb
68000-61-DF	Drinking Fountain in Locker Room 61	7.0	ppb
68000-61-UPPER-DF	Drinking Fountain in 2nd Floor Locker Room	4.2	ppb
68000-403-S	Sink in Instrument/Band Room 403	12.8	ppb
68000-403-SWB	Sink with Bubbler in Instrument/Band Room 403	0.4	ppb
68000-90-S	Sink in Clinic	1.0	ppb
68000-94H-DF	Hallway Drinking Fountain near Cafeteria	0.1	ppb
68000-416-S	Sink in Industrial Lab 416	3.6	ppb
68000-416-SWB	Sink with Bubbler in Industrial Lab 416	11.3	ppb
68000-101-S1	Food Service Sink - Sprayer	11.2	ppb
68000-101-S2	Food Service Sink - Wash/Rinse	2.7	ppb
68000-101-S3	Food Service Sink - Rinse/Sanitize	9.0	ppb
68000-102-S1	Food Service Sink - Food Prep	7.0	ppb
68000-102-S2	Food Service Sink - Food Prep	5.8	ppb
68000-102-S3	Food Service Sink - Hand Sink	2.7	ppb
68000-C2H-DFL	Hallway Drinking Fountain on 2nd Floor near Elevator/Left	10.1	ppb
68000-C2H-DFR	Hallway Drinking Fountain on 2nd Floor near Elevator/Right	1.2	ppb