

Wilmore-Davis Elementary School - Sampled 7/20/16			
CustomerSampleNumber	Description	Lead Result	Units
48000-171H-DFL	Hallway Drinking Fountain across from Classroom 139/Left	7.8	ppb
48000-171H-DFR	Hallway Drinking Fountain across from Classroom 139/Right	7.2	ppb
48000-140-S	Sink in Classroom 140	1.2	ppb
48000-140-SWB	Sink with Bubbler in Classroom 140	2.0	ppb
48000-141-S	Sink in Classroom 141	1.4	ppb
48000-141-SWB	Sink with Bubbler in Classroom 141	1.4	ppb
48000-144-S	Sink in Kindergarten Classroom 144	1.1	ppb
48000-144-SWB	Sink with Bubbler in Kindergarten Classroom 144	0.8	ppb
48000-143-S	Sink in Kindergarten Classroom 143	4.5	ppb
48000-143-SWB	Sink with Bubbler in Kindergarten Classroom 143	2.2	ppb
48000-142-S	Sink in Classroom 142	1.7	ppb
48000-142-SWB	Sink with Bubbler in Classroom 142	2.0	ppb
48000-139-S	Sink in Classroom 139	0.4	ppb
48000-139-SWB	Sink with Bubbler in Classroom 139	0.9	ppb
48000-138-S	Sink in Classroom 138	1.9	ppb
48000-138-SWB	Sink with Bubbler in Classroom 138	7.2	ppb
48000-132-S1	Food Service Sink-Hand Sink	1.0	ppb
48000-132-S2	Food Service Sink-Wash/Rinse/Sanitize	1.4	ppb
48000-154-S	Sink in Library Work Room	17.5	ppb
48000-151-S	Sink in Library	279.9	ppb
48000-151-SWB	Sink with Bubbler in Library	9.8	ppb
48000-134-DF	Drinking Fountain in Gym	1.7	ppb
48000-189-DFL	Hallway Drinking Fountain outside of Gym/Left	0.9	ppb
48000-189H-DFR	Hallway Drinking Fountain outside of Gym/Right	1.0	ppb
48000-111H-DFL	Hallway Drinking Fountain across from Clinic/Left	1.4	ppb
48000-111H-DFR	Hallway Drinking Fountain across from Clinic/Right	0.6	ppb
48000-107-S	Sink in Teacher's Lounge	1.8	ppb
48000-114-S1	Art Room Sink	4.0	ppb
48000-114-S2	Art Room Sink	0.5	ppb
48000-118-S	Sink in Classroom 118	8.4	ppb
48000-118-SWB	Sink with Bubbler in Classroom 118	5.0	ppb
48000-126-SWB	Sink with Bubbler in Classroom 126	4.0	ppb
48000-126-S	Sink in Classroom 126	6.9	ppb
48000-128-S	Sink in Classroom 128	417.8	ppb
48000-128-SWB	Sink with Bubbler in Classroom 128	6.8	ppb
48000-129-S	Sink in Classroom 129	47.9	ppb
48000-129-SWB	Sink with Bubbler in Classroom 129	8.3	ppb
48000-127-S	Sink in Classroom 127	442.8	ppb
48000-127-SWB	Sink with Bubbler in Classroom 127	6.1	ppb
48000-106X-S	Sink in Clinic	4.0	ppb
48000-132-S3	Food Service Sink-Sprayer	10.6	ppb
48000-REC-101-DF	Drinking Fountain in TEMP REC-101	0.2	ppb
48000-REC-068-DF	Drinking Fountain in TEMP REC-068	0.2	ppb