

Wilmot Elementary School - Sampled 7/19/16

CustomerSampleNumber	Description	Lead Result	Units
49000-101H-DFL	Hallway Drinking Fountain near Library/Left	1.0	ppb
49000-101H-DFR	Hallway Drinking Fountain near Library/Right	0.3	ppb
49000-113-S	Sink in Room 113	0.4	ppb
49000-113-SWB	Sink with Bubbler in Room 113	<0.1 *	ppb
49000-114-S	Sink in Kindergarten Classroom 114	0.7	ppb
49000-114-SWB	Sink with Bubbler in Kindergarten Classroom 114	<0.1 *	ppb
49000-115-S	Sink in Classroom 115	0.8	ppb
49000-115-SWB	Sink with Bubbler in Classroom 115	<0.1 *	ppb
49000-118-S	Sink in Resource Room 118	0.5	ppb
49000-118-SWB	Sink with Bubbler in Resource Room 118	0.2	ppb
49000-119-S	Sink in Classroom 119	0.5	ppb
49000-119-SWB	Sink with Bubbler in Classroom 119	0.5	ppb
49000-120-S	Sink in Classroom 120	0.5	ppb
49000-120-SWB	Sink with Bubbler in Classroom 120	<0.1 *	ppb
49000-121-S	Sink in Classroom 121	0.5	ppb
49000-121-SWB	Sink with Bubbler in Classroom 121	<0.1 *	ppb
49000-112H-DFL	Hallway Drinking Fountain across from Kindergarten Classroom 114/Left	0.7	ppb
49000-112H-DFR	Hallway Drinking Fountain across from Kindergarten Classroom 114/Right	1.3	ppb
49000-128-S	Sink in Teacher's Lounge	1.0	ppb
49000-131-S	Sink in Art Room	1.4	ppb
49000-132-SWB	Sink with Bubbler in Kindergarten Classroom 132	<0.1 *	ppb
49000-132-S	Sink in Kindergarten Classroom 132	2.5	ppb
49000-133-SWB	Sink with Bubbler in Kindergarten Classroom 133	<0.1 *	ppb
49000-133-S	Sink in Kindergarten Classroom 133	0.3	ppb
49000-139-S	Sink in Classroom 139	2.9	ppb
49000-140-S	Sink in Classroom 140	1.6	ppb
49000-141-S	Sink in Classroom 141	0.6	ppb
49000-144-S	Sink in Planning Room 144	0.5	ppb
49000-144-SWB	Sink with Bubbler in Planning Room 144	<0.1 *	ppb
49000-146-S	Sink in Classroom 146	0.5	ppb
49000-146-SWB	Sink with Bubbler in Classroom 146	0.5	ppb
49000-147-SWB	Sink with Bubbler in Classroom 147	<0.1 *	ppb
49000-147-S	Sink in Classroom 147	0.2	ppb
49000-134H-DFR	Hallway Drinking Fountain across from Classroom 147/Right	0.3	ppb
49000-148-S	Sink in Classroom 148	0.7	ppb
49000-148-SWB	Sink with Bubbler in Classroom 148	0.4	ppb
49000-152-S	Sink in Workroom 152	0.9	ppb
49000-156-S	Sink in Clinic	1.5	ppb
49000-165-S1	Food Service Sink-Food Prep	6.8	ppb
49000-165-S2	Food Service Sink-Hand Sink	19.4	ppb
49000-165-S3	Food Service Sink-Wash/Rinse	1.8	ppb
49000-165-S4	Food Service Sink-Sprayer	3.5	ppb
49000-B101-S	Sink in Classroom B101	0.7	ppb
49000-B101-SWB	Sink with Bubbler in Classroom B101	<0.1 *	ppb
49000-B101A-S	Sink in Classroom B101A	0.3	ppb
49000-B101A-SWB	Sink with Bubbler in Classroom B101A	<0.1 *	ppb
49000-B102-S	Sink in Classroom B102	0.2	ppb

49000-B102-SWB	Sink with Bubblers in Classroom B102	<0.1 *	ppb
49000-B100H-DFL	Hallway Drinking Fountain across from Classroom B101A/Left	0.3	ppb
49000-B100H-DFR	Hallway Drinking Fountain across from Classroom B101A/Right	1.7	ppb
49000-B106-S	Sink in Resource Room B106	0.7	ppb
49000-B106-SWB	Sink with Bubblers in Resource Room B106	0.2	ppb
49000-B107-S	Sink in Classroom B107	0.2	ppb
49000-B107-SWB	Sink with Bubblers in Classroom B107	<0.1 *	ppb
49000-B108-S	Sink in Classroom B108	0.3	ppb
49000-B108-SWB	Sink with Bubblers in Classroom B108	<0.1 *	ppb
49000-B109-S	Sink in Classroom B109	0.3	ppb
49000-B109-SWB	Sink with Bubblers in Classroom B109	0.9	ppb
49000-B180X-S	Sink in Music Room	5.6	ppb
49000-B180X-SWB	Sink with Bubblers in Music Room	8.5	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.